

C-7

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/NDZ/ 1076

Dated: 24/12/2021

FIRE SAFETY CERTIFICATE

Certified that the K.V. Vidya Mandir, H-9/2, Mansarovar Park, Shahdara, Delhi - 110032, comprised of ground plus two upper floors owned/occupied by K.V. Vidya Mandir was issued FSC vide letter No. F.6/DFS/MS/06/2214 dated 25/08/2006. The school building was re-inspected by the officer concerned of this department on 22/12/2021 in the presence of Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No.262-362 Dated-17/01/05 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground plus two upper floors with effect from 24/12/2021 for a period of **three** years, subject to conditions, printed below.

Issued on..... 24/12/2021 at New Delhi by


24/12/21

(Dr. S.K.Tomar)
Dy. Chief Fire Officer



Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time. o/c
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

To,

The Manager,
K.V. Vidya Mandir, H-9/2, Mansarovar Park, Shahdara, Delhi -110032

Copy:-

The Dy. Director of Education
B-Block, Yamuna Vihar, North-East, Delhi-110053

N/1

1. Name & address of the building : K.V. Vidya Mandir, H-9/2, Mansarovar Park, Shahdara, Delhi-32
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/06/2214 dt 25/08/06
6. Fire Safety direction letter No : Circular No. 262-363/Dir.of Edu. Dated 17/01/2005
7. Date of Inspection : 22/12/2021
8. Name of the Inspecting officers : A.D.O Mehmood
9. Name and designation of Officer from the building side : Ms. Poonam Sharma, Principal
10. Year of Construction : 1989
11. Applicant's letter No : Email, Dated-12/11/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	06 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	01 Nos.	02 Nos.	MR
	• Basement	N/A	N/A.	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr.	0.83 mtr & 0.80 mtr	MR (Accepted as old case)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01Nos.	01 Nos.	MR
	e. Width of Corridor	1.50 mtr.	0.84 mtr.	MR (Accepted as old case)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	06 nos.	06 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the pump	40 M	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 Ltr.	5,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Firemen's grounding switch Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Battery backup Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular no. 262-362 dated 17/01/2005 issued by Director of Education, it is recommended to renew Fire Safety Certificate under the rule 35 of Delhi Fire Service rules 2010.

Handwritten note: Previous file is missing on DO (CBO) is not send to us, we may approval of the case is a renewal only of 12 to 6 old doc copy submitted by party

Signature of the Inspecting Officer
 Name - Mehmood
 Designation - ADO (T.P)

Dy.CFO (NDZ)
Signature
 23/12/21



ADO (T.P)
 A. P. T. letter put up for signature please

Dy. (B.O. C.A.O. 2)
Signature
 24/12/21

Signature
 28/12/21
 ADO (T.P)

ms