

C-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No F 6 DFS/MS/School/2021/SZ/1052

Dated: 21/12/2021

FIRE SAFETY CERTIFICATE

Certified that **Maya Goel Vidya Niketan**, located at G-70, Sangam Vihar, New Delhi-110080 comprised of **Basement, Ground plus Two upper floors** owned / occupied by **Maya Goel Vidya Niketan** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2014/SZ/1595 Dated 17/12/2014. The said premise was re-inspected by officer concerned of this department on 16/12/2021 in presence of Mr. Mohit Goel of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act-2007 & Rules-2010 and the building is fit for occupancy class "**Educational Building Group – B**" with effect from 21/12/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 21/12/2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Maya Goel Vidya Niketan, G-70, Sangam Vihar, New Delhi-110080
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Maya Goel Vidya Niketan, G-70, Sangam Vihar, New Delhi-110080.		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 02 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2014/SZ/1595 Dated 17/12/2014		
6	Fire Safety Directives Letter No	DOE Circular Dated 01/03/2021		
7	Date of Inspection	16/12/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Mohit Goel		
10	Year of construction	2005-06		
11	Applicant letter No.	F6/2021-22/MGVN/68 Dated 06/12/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	M/R
	➤ Basement floor.	02 Nos	02 Nos	M/R
	b) Width of Staircase			
	➤ Upper floor	1.50m /0.75m	1.50m & 1.0m	M/R (old case)
	➤ Basement floor	1.50m /0.75m	1.50m & 1.40m	M/R (old case)
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 Nos	MR
	e) Width of corridor	1.5 mtr	Provided	MR
	f) Door size	1.0 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI mark	12 No's	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.		02 No	M/R
	• Length of hose-reel hose.	Hose reel	30m	M/R
	• Nozzle Diameter		5mm	M/R
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-

#112

	<ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. • Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		20,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 376 dated 18/01/2019.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2014/SZ/1595 Dated 17/12/2014, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh
16/12/2021

Signature of Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

Sh
16/12/21

DCFO (S2)

F.T.
Sh

~~A DO (BCP)~~

As approved, F.T. letter is put up for your signature @

Sh
20/12

Sh
16/12/21

M.S. *Sh*