

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 1053

Dated: 22/12 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that **Swarn Public School**, located at **171-A, Main Khirki Road, Malviya Nagar, New Delhi-110017** comprised of Basement, Ground plus Two upper floors (**Basement not used for school purpose**) owned / occupied by **Swarn Public School** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/833 Dated 09/06/2017. The said premise was re-inspected by officer concerned of this department on 16/12/2021 in presence of Mrs. Dayal P. Gurwara (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and the building is fit for occupancy class "**Educational Building Group – B**" with effect from 22/12 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 22/12.2021 at New Delhi by

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Swarn Public School, 171-A, Main Khirki Road, Malviya Nagar, New Delhi-110017.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

### INSPECTION REPORT

1	Name & Address of the Building	Swarn Public School, 171-A, Main Khirki Road, Malviya Nagar, New Delhi-110017.		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 02 Upper Floors <b>(Basement not used for school purpose)</b>		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/833 Dated 09/06/2017		
6	Fire Safety Directives Letter No	DOE Circular Dated 01/03/2021		
7	Date of Inspection	16/12/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Dayal P. Gurwara (Principal)		
10	Year of construction	1997		
11	Applicant letter No.	Nil dated 09/12/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	06 mtr	Provided	MR
	• Gate width	-NA-	3.65 m & 3 m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	02 Nos	M/R
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floor	1.50m /0.75m	1.30m & 0.90m	M/R (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	02 Nos	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1.0 mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	NA	NA
	• Upper floors	12 ACPH	-NA-	-NA-
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	ISI mark	15 No's	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.		01 No	M/R
	• Length of hose-reel hose.	Hose reel	30m	M/R
	• Nozzle Diameter		5mm	M/R
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	-NA-	-NA-	-NA-
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	Required	100 mm	MR
		-NA-	01	-NA-
		-NA-	01	-NA-
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul>	450 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>• Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2017/SZ/833 Dated 09/06/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Handwritten signature and date: 29/12/2021*

Signature of Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Design: ADO (BCP)

DO (SD) — on leave F.T.,

*Handwritten signature and date: 21/12*

*Handwritten signature and date: 21/12*

*Handwritten text: (A D O / B C P)*

As approved, f.t. letter is put up for your signature pl

*Handwritten signature and date: 21/12*

*Handwritten signature and date: 21/12*

*Handwritten text: M.S. cell*