

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. E.6/DFS/MS/EH/2021/SZ/ 383

Dated: 29 / 12 /2021

FIRE SAFETY CERTIFICATE

Certified that **TACO BELL** (A Unit of Burman Hospitality Pvt Ltd.) Located at Ground floor, Shop No E-153, Kalkaji Delhi 110019 in a building comprised of Basement, Ground plus two upper floor owned/occupied (A Unit of Burman Hospitality Pvt Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 22/12/2021 in the presence of Mr. Avnish (Manager) and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant running at Ground floor only)** with effect from 29 / 12 /2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29 / 12 /2021 at New Delhi by

(ATUL GARG)
DIRECTOR DFS

Copy to: -

1. The Dy. Health Officer, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi 110016. (Ref. MHA Portal ID 2021111926786 dated 19/11/2021)
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi 110049.
3. **TACO BELL** (A Unit of Burman Hospitality Pvt Ltd.) Located at Ground floor, Shop No E-153, Kalkaji Delhi 110019

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	TACO BELL (A Unit of Burman Hospitality Pvt Ltd.) at Shop No E-153, Kalkaji Delhi 110019		
2	Type of Occupancy	Group-D Assembly Building.		
3	Building Comprised of	Basement, Ground Plus two upper floor		
4	Type of Case	(Restaurant running at ground floor only) ✓		
5	Details of Previous NOC	New case		
6	Fire Safety Directives Letter No	nil		
7	Date of Inspection	UBBL-2016 / NBC Part-IV		
8	Name of the Inspecting Officers	22/12/2021		
9	Name & Designation of Officers from the building side	Sh. Rajesh Kumar, ADO (BCP)		
10	Year of construction	Mr. Avnish (Manager)		
11	Applicant letter No.	1985		
		MHA Portal ID 2021111926786 dated 19/11/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required N/A N/A	9m Accessible from road N/A	MR ✓ N/A N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	Other property	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	One	MR ✓
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 mtr x 2	1.50 mtr each	MR ✓
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	06 Nos	06 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	Provided	N/A
	• Location of Main Panel	N/A	Provided	N/A

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	NA	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	Other property	NA
	<ul style="list-style-type: none"> Ground floor. 	NA	Provided	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	One	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of pump. 	40 m	Provided	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow switch panel. 	N/A	N/A	N/A
		N/A	N/A	N/A

	<ul style="list-style-type: none"> PA system panel. Battery backup. Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]
28/12

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

~~DO (SD)~~

[Handwritten Signature]
28/12/21

~~DeFO (S2)~~

[Handwritten Signature]
29/12

CFO D (off)

Director *[Handwritten Signature]*
29/12/21. ATPS

ADU/MSPP

F.T. letter is put up for sig. pl.

[Handwritten Signature]
29/12

~~W Director *[Handwritten Signature]*~~
29/12/21
m