

C-188

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2021/SZ/ GH/536

Dated: 20/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust) located at Circular Road, Chanakyapuri, New Delhi-110021, comprised of Basement, Ground & Four Upper Floors only owned / occupied by M/S Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust), was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2018/SZ/2283 dated 09.10.18. The premises was re-inspected by the officer concerned of Fire Service on 06/12/2021 in the presence of Sh. B.S.Rathore (Hostel Supervisor) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Residential" (Group-A) with effect from 20/12/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 20/12/2021 at New Delhi by

  
 (ATUL GARG)  
 DIRECTOR.

Copy to :-

1. Authorized Signatory, M/S Vishwa Yuvak Kendra (U/o Indian Youth Centres Trust), Circular Road, Chanakyapuri, New Delhi-110021.
2. The Joint Commissioner of Police (Lic.), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-110049.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".  
 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

mf 58

**INSPECTION REPORT**

1. Name & address of the building : M/S Vishwa Yuvak Kendra (A Unit of Indian Youth Centres Trust) at, Circular Road, Chanakyapuri, New Delhi-110021.
2. Building comprised of : B+G+4Upper floors.
3. Type of Occupancy : Group "A" Residential Dormitory Building.
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/GH/2018/SZ/2283 dated 09.10.18.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 06/12/2021
8. Name of the Inspecting Officers: : A.K. Jaiswal (ADO).
9. Name and designation of Officer from the building side : Sh. B.S.Rathore (Hostel Supervisor).
10. Year of Construction : 1969.
11. Applicant's letter received through email ID-vyk@vykonline.org dated 11/11/2021.

S.No	Minimum Standards on fire prevention and fire safety as per Rule 33.	Requirement	Provided at Site	Remarks MR/NMR	
1	Access to building				
	Road width	6 m	10m	MR	
	Gate width	4.5m.	4.5m.	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	Number, Width, Type and Arrangement of Exits.				
	a. Number of Staircases Upper Floor	Upto 1 <sup>st</sup> floor=02nos. 1 <sup>st</sup> floor to terrace=3nos.	Upto 1 <sup>st</sup> floor=02nos. 1 <sup>st</sup> floor to terrace=3nos.	MR	
	Basement	02nos	02nos.	MR	
	B. Width of Staircases Upper Floor	1.25m(two)	1.27m, 1.23m & 60cm from 1 <sup>st</sup> floor to terrace.	MR (old case)	
	Basement	1.25m	1.5m & 1.27m	MR	
	c. Protection of exits	Required	Provided	MR	
	Fire check door	Required	Provided	MR	
	Pressurization	N.A.	N.A.	N.A.	
	e. No. of continuous staircases to terrace	1no.	2nos.	MR	
	g. Width of Corridor	N.A.	N.A.	N.A.	
	h. Door Size	1mtr.	1mtr.	MR	
	3	Compartmentation			
		Fire check door	N.A.	N.A.	N.A.
Sealing of electrical shafts		Required	Provided	MR	
Fire rating of shaft door		N.A.	N.A.	N.A.	
Water curtain		N.A.	N.A.	N.A.	
Fire Dampers		N.A.	N.A.	N.A.	
4	Smoke Management System.				
	Basement	30a/c per hour	Exhaust fan Provided	MR	
	Upper floor	15 a/c per hour	Natural Ventilation	MR	

11/59

M/S Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-21.

5.	Fire Extinguisher			
	Total numbers	24 nos.	30 nos.	MR
	Types	ABC&WCO <sub>2</sub>	ABC&WCO <sub>2</sub>	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02nos.	02nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	900LPM	900LPM	MR
	➤ Head of Main Pump	70m	70m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900LPM	900 & 180 LPM(two set)	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR



m/- 60

M/S Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-21.

14	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	50000Liters	50000Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters	10000+10000Liters	MR
15	Exit Signage.	Required	Provided	M R
16	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided ( DG Set)	M R
18	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/GH/2018/SZ/2283 dated 09.10.18 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*[Signature]*  
8/12/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)



*[Signature]*  
D O / (S.J.)

*[Signature]*  
10/12/21

*[Signature]*  
DeFO / (S.J.)

*[Signature]*  
14/12

*[Signature]*  
G.F.O.

*[Signature]*  
10/12  
14/12/21

*[Signature]*  
DySO

P.F.O