

c-33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE**  
**CONNAUGHT PLACE: NEW DELHI-110001**

No. F.6/DFS/MS/11/2021/SZ/ 376

Dated: 23/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the name & style of M/s **Gourmet Greens** (A Unit of N Square Hospitality LLP) at Ground Floor, Shop No. 19, 20 & 21 Savitri Cinema Complex DLF Center, Greater Kailash Part II, New Delhi 110048, comprised of Basements, Ground & 03 Upper Floors but the Restaurant located at Ground Floor only has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 16/12/2021 in the presence of Mr. Satish Kumar (Manager) of the restaurant and that the premises is fit for occupancy class "**Assembly, Group-D**" (Restaurant) with effect from 23/12/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/12/2021 at New Delhi by

  
(Atul Garg)  
**Director**  
**Delhi Fire Service**

Copy to: -

1. The Dy. Health Officer, South MCD, Public Health Department, South Zone, Aurobindo Marg, Green Park, New Delhi-110016 [w.r.t online ID: 2021120227639 dated 02/12/2021]
2. M/s Gourmet Greens (A Unit of N Square Hospitality LLP) at Ground Floor, Shop No. 19, 20 & 21 Savitri Cinema Complex DLF Center, Greater Kailash Part-2, New Delhi-110048

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

- 2/7 -  
**INSPECTION REPORT**

1	Name & Address of the Building	M/s <b>Gourmet Greens</b> (A Unit of N Square Hospitality L.L.P) at Ground Floor, Shop No. 19, 20 & 21 Savitri Cinema Complex DLF Center, Greater Kailash Part-2, New Delhi-110048												
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)												
3	Building Comprised of	Basements, Ground + 02 Upper Floors <b>but Eating House is located at Ground Floor only</b>												
4	Type of Case	New												
5	Details of Previous NOC	Nil												
6	Fire Safety Directives Letter No	F.6/MS/DFS/BP/Cinema/2000/1676 Dt. 19/09/2000												
7	Date of Inspection	16/12/2021												
8	Name of the Inspecting Officers	DO (SD)												
9	Name & Designation of Officers from the building side	Sh. Satish Kumar (Manager)												
10	Year of construction	1976												
11	Applicant letter No.	Online ID 2021120227639 dated 02/12/2021												
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC/UBBL Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>										
<b>1</b>	<b>Access to Building.</b>	<b>F.6/DFS/MS/Cinema/2020/SZ/240 Dt. 08/07/2020</b>												
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Eating House within Savitri Cine Complex	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> </table>	Provided	MR	-NA-	-NA-	-NA-	-NA-					
Provided	MR													
-NA-	-NA-													
-NA-	-NA-													
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>													
	<b>a) Number of Staircase</b>	Provided and Maintained by Bldg. Mgmt.												
	<ul style="list-style-type: none"> <li>➤ Upper floors.</li> <li>➤ Basement floor.</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;"><b>Restt. at GF only</b></td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">N/A</td> <td style="text-align: center;">-NA-</td> </tr> </table>	-NA-	<b>Restt. at GF only</b>	-NA-	-NA-	N/A	-NA-						
-NA-	<b>Restt. at GF only</b>	-NA-												
-NA-	N/A	-NA-												
	<b>b) Width of Staircase</b>	Provided and Maintained by Bldg. Mgmt.												
	<ul style="list-style-type: none"> <li>➤ Upper floors</li> <li>➤ Basement floor</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> </table>	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-						
-NA-	-NA-	-NA-												
-NA-	-NA-	-NA-												
	<b>c) Protection of exits</b>	Provided and Maintained by Bldg. Mgmt.												
	<ul style="list-style-type: none"> <li>➤ Fire check door</li> <li>➤ Pressurization</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> </table>	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-						
-NA-	-NA-	-NA-												
-NA-	-NA-	-NA-												
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-										
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-										
	<b>f) Door size</b>	1.5m (2 exits)	Provided	MR										
<b>3</b>	<b>Compartmentation.</b>													
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Required</td> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> </table>	Required	Provided	MR	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-	-NA-
Required	Provided	MR												
-NA-	-NA-	-NA-												
-NA-	-NA-	-NA-												
-NA-	-NA-	-NA-												
<b>4</b>	<b>Smoke Management system.</b>	Provided and Maintained by Bldg. Mgmt.												
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">30 ACPH</td> <td style="text-align: center;">-NA-</td> <td style="text-align: center;">-NA-</td> </tr> <tr> <td style="text-align: center;">12 ACPH</td> <td style="text-align: center;">Exhaust Fans Provided</td> <td style="text-align: center;">MR</td> </tr> </table>	30 ACPH	-NA-	-NA-	12 ACPH	Exhaust Fans Provided	MR						
30 ACPH	-NA-	-NA-												
12 ACPH	Exhaust Fans Provided	MR												
<b>5</b>	<b>Fire Extinguishers.</b>													
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Required</td> <td style="text-align: center;">10 Nos</td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">ABC/CO<sub>2</sub></td> <td style="text-align: center;">ABC &amp; CO<sub>2</sub></td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">Required</td> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> </table>	Required	10 Nos	MR	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR	Required	Provided	MR			
Required	10 Nos	MR												
ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR												
Required	Provided	MR												
<b>6</b>	<b>First Aid Hose Reels.</b>	Provided and Maintained by Bldg. Mgmt.												
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">One near Restt.</td> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">30m</td> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> <tr> <td style="text-align: center;">5mm</td> <td style="text-align: center;">Provided</td> <td style="text-align: center;">MR</td> </tr> </table>	One near Restt.	Provided	MR	30m	Provided	MR	5mm	Provided	MR			
One near Restt.	Provided	MR												
30m	Provided	MR												
5mm	Provided	MR												

7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	-NA-	-NA-	-NA-
10	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>	Provided and Maintained by Bldg. Mgmt.		
	• Size of Riser/Down-comer	Required	Provided	MR
	• Number of Hydrant per floor	One near Restt.	Provided	MR
	• Hose box.	One near Restt.	Provided	MR
12	<b>Yard Hydrants.</b>	Provided and Maintained by Bldg. Mgmt.		
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	<b>a) Ground Level</b>	Provided and Maintained by Bldg. Mgmt.		
	➤ Discharge of main pump.	-NA-	2850 LPM	-NA-
	➤ Head of main pump.	-NA-	70m	-NA-
	➤ Number of main pumps.	-NA-	One	-NA-
	➤ Jockey Pump output.	-NA-	180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	70m	-NA-
	➤ Standby Pump output.	-NA-	2850 LPM	-NA-
	➤ Standby Pump head.	-NA-	70m	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump house access.	-NA-	Provided	-NA-
	<b>b) Terrace Level</b>	Provided and Maintained by Bldg. Mgmt.		
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	40m	40m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>	Provided and Maintained by Bldg. Mgmt.		
	• Underground tank capacity.	-NA-	2,00,000 Ltr	-NA-
	➤ Draw-off connection.	-NA-	Provided	-NA-
	➤ Fire Service Inlet.	-NA-	Provided	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	20,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	Provided and Maintained by Bldg. Mgmt.		
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19	<b>Fire Control Room.</b> <ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	Provided and Maintained by Bldg. Mgmt.		
		-NA-	Provided	-NA-
		-NA-	-NA-	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
		-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

*S.K. Dua*  
28/12/11

Signature of the Inspecting Officer  
 Name : S. K. Dua  
 Designation: DO (SD)

DCFO (SZ)

*S.K. Dua*  
21/12

(F.O. (D. off))

Director  
*S.K. Dua*  
22/12/11

FT Dh  
 D/S

F.S.C. letter is put up for signature please.

Director  
*S.K. Dua*  
29/12/2011  
 uploaded