

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/2021/WZ/ 629

Dated: 21/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation Ltd** located at **Rithala Metro Station, Rohini, Delhi-85**, comprised of **Ground + Concourse + Platform** owned/occupied by **Delhi Metro Rail Corporation Ltd.** has already been issued FSC by this department vide letter No. **F.6/MS/DFS//2008/182 dated 23.11.2008**. The premises was re-inspected by the officer concerned of this department on **07.12.2021** in the presence of **Mr. Vikash Bhardwaj** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class '**D**' **Assembly Building** with effect from 21/12/2021 for a period of **03 (three) years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/12/2021..... at New Delhi by


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to :-

1. Sh. Vivek Shrivastwa (JGM/E&M), Delhi Metro Rail Corporation Ltd. Metro Bhawan, 13, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Delhi Metro Rail Corporation Ltd located at Rithala Metro Station Rohini, Delhi-85.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal **Ground + Concourse + Platform**
4. Details of Previous NOC : F.6/MS/DFS//2008/182 dated 23.11.2008
5. Fire Safety directives letter No : F.6/MS/DFS/BP/2004/2135 dated 16.09.2004
6. Date of inspection : 08.12.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr.Vikash Bhardwaj
9. Year of Construction :
10. Applicant's letter No. : Online e-mail dated 22.11.2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DFS Rules 35(6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	24m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	6.0m	6.0m	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Gr. to Concourse-04 Con to platform-04	04 04	MR MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	Required	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization			
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	Required	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	Required	Provided	MR
	➤ Head of Main pump	Required	Provided	MR
	➤ Number of main pumps			
	➤ Jockey Pump out put	Required	Provided	MR
	➤ Jockey pump head	Required	Provided	MR
	➤ Standby Pump out put	Required	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	5,00,00ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

NI 10

Special Fire Protection System for Protection of special Risks, if any:

Co2 flooding in panel

Provided

MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/MS/DFS//2008/182 dated 23.11.2008 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
10/12/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajay
15/12/2021

Devo (W2)

Ajay
17/12/2021

~~ADO~~ Rohini

FT letter is put up for kind perusal and signature please.

Devo (W2)

Ajay
21/12/2021

Ajay
21/12/21

MSJ