

E52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/ NDZ/ 1099

Dated: 31/12/21

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Senior Secondary School at Dayal Pur, Delhi -110094, comprised of ground plus one upper floor only owned/occupied by Govt. Girls Senior Secondary School was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/536 dated 14/03/19. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Abdul Salam Khan (Estate Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No-F16/Estate/CC/FS/2011/3298to3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 31.12.21..... for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....31.12.21..... at New Delhi by


30/12/21

(Dr. S.K Tomar)
Dy.Chief Fire Officer

To,
The Principal,
Govt. Girls Senior Secondary School,
Dayal Pur, Delhi -110094

o/c 

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Govt. Girls Senior Secondary School,
Dayal Pur, Delhi-110094
2. Building is comprised of : Ground plus first floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2019/NDZ/536 dt 14/03/19
6. Fire Safety direction letter No : Circular dated 01/03/11 issued by DoE
7. Date of Inspection : 23/12/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Abdul Salam Khan(Estate Manager)
10. Year of Construction : 1999
11. Applicant's letter No : GGSSS/DP/2021/646, Dated-16/12/2021

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06 mtr.	12 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	03 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr. each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A.	N/A	N/A
	e. Width of Corridor	1.50 mtr.	3.20 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers types 	15 nos.	18 nos.	MR
	<ul style="list-style-type: none"> IS marking 	ABC /CO ₂	ABC /CO ₂	MR
06	First-aid-Hose Reels.			
		ISI marked	ISI marked	MR
	Total numbers on each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main Pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump Head Auto Starting /Manual stopping Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of the Pump Power supply Auto Starting of pump 	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular No- F16/Estate/CC/Fire Safety/2011 /3298to3398 dt-01/03/11, it is recommended to renewal of Fire Safety Certificate under the rule 35 of Delhi Fire Service rules 2010.





Signature of the Inspecting Officer

Name - Mehmood

Designation - A.D.O(T.P)

Dy.CFO(NDZ)



 24/12/21
 ADO(TP) Sir, A.O.T & placed for Signatures

 30/12/21
 30/12/21
 ADO(TP)

MS