

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F6/DFS/MS/2021/ School/ W2/1095

Dated: 31/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Boys Sr. Sec. School, (I.D No.1207109)** located at **Magazine Road Majnu Ka Tilla, Delhi-110054** comprised of **(02 New Blocks) ground and 03 upper floors** each owned/ occupied by the **Govt. Boys Sr. Sec. School** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **18.12.2021** in the presence of **Sh. Vishal Sharma (Attendant)** and that the building/premises is fit for occupancy Class **“Group B Educational”** with effect from ...31.12.21... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...31.12.21... at New Delhi


(Atul Garg)
Director
Ph:-011-23414000
etc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Assistance Engineer (E), PWD Sub-Division 4, Edu. Electrical Edn. 1 Division (N), Zakhira, Rama Road, Delhi-110015.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form “K”** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form ‘J’** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. school, Magazine Road Majnu Ka Tilla, Delhi-110054.
2. Composition of building : (02 New Blocks) Ground + 03 upper Floors Only (School ID. No-1207109)
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-4
7. Date of inspection : 18.12.2021
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Vishal Sharma (Attendant)
10. Year of Construction : 2020
11. Applicant's letter No. : No.54(13)/A.E.(E)-4/P.W.D/M-1/2021-22/127 dated: 08.12.2021

Plot Area:11400Sqm Covered Area: 3281 Sqm No. of Student: NO. of Class Room:

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	06m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.80m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.5m	1.60	MR
	f. Door Size	1.20m	1.20m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	16nos	18nos	MR
	• Types	ABC/Co2	ABC-14 Co2-04	MR
	• ISI marking	ISI Marked	Provided	MR



6	First-Aid Hose Reels			
	• Total numbers on each floor	02 each block	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	N/A	NA
	➤ Jockey pump head	NA	N/A	NA
	➤ Standby Pump out put	NA	N/A	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	450 lpm x 02 Provided	MR
	➤ Head of the pump	40m	40m	MR
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	N/A	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA


	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltr each block	10,000 ltr each block	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV/Director of Education dated 01.03.2016, it is recommended to grant Fire Safety Certificate



DO (N/W)


 24/12/2021
 By CFO (W2)

 24/12/2021


 20/12/2021

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN




 28/12

 28/12/2021
