



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/Education/2021/SZ/ 631

Dated: 21/12/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Jagan Nath Gupta Memorial Educational Society, situated at MOR Pocket-105, Kalkaji, New Delhi-110019** comprised of **Basement, Ground and Four upper floors** owned/ occupied by Jagan Nath Gupta Memorial Educational Society was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Education/SZ/2018/1354 dated 11/06/2018. The said premises was re-inspected by officer concerned of this department on 08/12/2021 in presence of Mr. Amit Kamra (Admin) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 21/12 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 21/12 2021 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

Copy to: -

1. Sh. Amit Gupta, Jagan Nath Gupta Memorial Educational Society, situated at MOR Pocket-105, Kalkaji, New Delhi-110019
2. The Executive Engineer (Bldg) SDMC, Jal Vihar, Lajpat Nagar, New Delhi 110024

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/24

**INSPECTION REPORT**

1. Name & address of the building : Jagan Nath Gupta Memorial Educational Society, MOR Pocket-105, Kalkaji, New Delhi-110019
2. Type of Occupancy : Class- B (Educational)
3. Type of Case : Renewal [Educational]
4. Details of Previous NOC : F6/DFS/MS/Education/SZ/2018/1354 dated 11/06/2018
5. Fire Safety directives letter No : F6/DFS/MS/BP/2008/2612 dated 16/09/2008
6. Date of inspection : 08/12/2021
7. Name of Inspecting Officer : Sh. Rajesh Kumar
8. Name and designation of officers  
From the building side : Mr. Amit Kamra
9. Year of Construction : 2000 & 2011 [Basement + Ground + 4 upper floors]
10. Applicant's letter No. : Gmail dated 08/12/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC/Directives Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	9m 5m 6m	9m 4.87m & 4.37m Provided	MR MR (Old Case) MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 Nos 02 Nos	02 Nos 03 Nos	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.5m(each) 1.5m(each)	1.56m & 1.12m 1.56m, 1m & 0.79m	MR (old case) MR (old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required in one staircase -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	01 Nos	01 Nos	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	1m (final exit)	-NA-
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required -NA- -NA- Required	Provided Provided -NA- -NA- Provided	MR MR -NA- -NA- MR
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust Fan -NA-	MR -NA-
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	25 No's ABC/W. CO <sub>2</sub> /CO <sub>2</sub> ISI	25 No's 10/10/05 No's Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30m 5mm	Two Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
8.	<b>MOEFA</b>	Required	Provided	MR

9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100mm	Provided	MR
		One	Two	MR
		One	Two	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	-NA-	01 Nos	-NA-
		-NA-	01 Nos	-NA-
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	900 LPM	900 LPM & 450 LPM	MR
		70m	35m	MR (Old Case)
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		25,000 Lts.	30,000 Lts.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provide	MR
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-NA-	-NA-	-NA-



N/96

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Education/SZ/2018/1354 dated 11/06/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Signature*  
8/12/2021

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD)


*Signature*  
08/12/21

*Signature*  
DeFO (SD)

*Signature*  
14/12

*Signature*  
CFO

*Signature*  
15/12



*Signature*  
16/12/21

*Signature*  
ADY MCD

As approved, Gt. letter is  
prepared for your signature PI

*Signature*  
20/12

*Signature*  
Director