

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/Auditorium/2021/ 637

Dated: 27/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **Triveni Kala Auditorium & Triveni Amphitheatre/Triveni (Open Air Theatre)** located at **205, Tansen Marg, New Delhi** comprised of Auditorium block (B + Gr. + Mezz. + 02 Upper floors) & Amphitheater block (B+ Gr. + 02 upper floor) owned/occupied by Triveni Kala Auditorium was earlier granted FSC by this department vide letter no.F6/DFS/MS/NDZ/Auditorium/2019/117 dated **16/01/19**. Now the premises was re-inspected by the officer concerned of this department on 17/12/21 in the presence of Sh. Suresh Gupta (Account Officer) and found that the said auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for Class -**Assembly and Business** occupancy with effect from **27.12.2021**....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ...**27.12.2021**..... at New Delhi by.


27/12/21

(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defence Colony, New Delhi.
2. Sh. Suresh Gupta (Account Officer),
Triveni Kala Auditorium at 205, Tansen Marg, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

11.1
M/G2

INSPECTION REPORT

1. Name & address of the building : Triveni Kala Auditorium & Triveni Amphitheatre/Triveni (Open Air Theatre) at 205, Tansen Marg, New Delhi
2. Type of occupancy : Assembly & Institutional (two block Auditorium block (B + Gr. + Mezz. + 02 Upper floors) Amphitheater block (B+ Gr. + 02 upper floor)
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/NDZ/Auditorium/2019/117 Dated 16/01/19.
5. Fire safety directives No. : NA
6. Date of inspection:- 17/12/21
7. Name of the inspecting officer : Sh. Ravinder Singh ADO(CC)
Sh. Rajinder Atwal DO (CD)
8. Name & designation of officer From the building side : Sh. Suresh Gupta (Account Officer)
9. Year of construction : 1975
10. Applicant's letter No : triveniks205@gmail.com Dated 08/12/21.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangemets	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	12 Mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3)Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No in each block	02 No in each block	MR
	2. Basements	02 No in each block	02 No in each block	MR
	B. Width of staircase			
	1. Upper floors	0.77 & 1.40 mtr.	0.77 & 1.40 mtr.	MR
	2. Basements	1.70 & 1.22 mtr.	1.70 & 1.22 mtr.	MR
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	NA
	F. Door size	1.80 & 1.90 Mtr.	1.80 & 1.90 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 ACPH	Neutral	MR

11/63

5.	Fire Extinguishers			
	1) Total numbers	35 Nos.	35 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 No. & 03 in audit	02 No. & 03 in audit	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	Generator	Provided	MR
	5) Hooter's Location	Near gate	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	02nos	02nos	MR
	3) Hose box each floor	02nos	02nos	MR
12.	Yard Hydrants			
	1) Total number of hydrants	NA	NA	NA
	2) Hose box	NA	NA	NA
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	NA	NA	NA
	b) Head of main pump	NA	NA	NA
	c) Number of main pump	NA	NA	NA
	d) Jockey pump out put (2 Nos.)	NA	NA	NA
	e) Jockey pump head	NA	NA	NA
	f) Stand by pump output	NA	NA	NA
	g) Stand by pump head	NA	NA	NA
	h) Auto starting/Manual stopping	NA	NA	NA
	2) Terrace level			
	a) Discharge of pump	01 Nos. 1630 LPM & 01 Nos. 1250 LPM	01 Nos. 1630 LPM & 01 Nos. 1250 LPM	MR

R ✓

	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	NA	NA	NA
	a) Draw-off connection	NA	NA	NA
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	NA	NA	NA
	d) Over head tank capacity	25,000 Ltrs.	25,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: 02 ABC fire extinguishers Near elect. Panel.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/NDZ/Auditorium/2019/117 dated 16/01/19, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Rajinder Atwal
 Name :- Rajinder Atwal
 Designation :- DO /CD

Ravinder Singh
 Name :- Ravinder Singh
 Designation :- ADO (CC)



Syfto (NDZ)
Rajinder Atwal
 24/12/21

ADO (CC) As approved per reply for K&S power and system phase.

Rajinder Atwal
 24/12/21

Rajinder Singh
 24/12/21