

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Mixed/2021/SZ/ 630

Dated: 21 / 12 / 2021

FIRE SAFETY CERTIFICATE

Certified that the U.P. Bhawan located at 5, Sardar Patel Marg, New Delhi-110021, comprised of Basement, Ground & 3 Upper Floors only, owned / occupied by U.P. Government, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/93/926 dated 25/05/1993. The premises was re-inspected by the officer concerned of Fire Service on 10.12.2021 in the presence of Sh. Arjun (UPRNN) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Mixed" (Business & Residential) with effect from 21 / 12 / 2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

Issued on 21/12/2021 at New Delhi by.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Smt. Archana Singh (Addl. Project Manager), UP Rajkiya Nirman Nigam Ltd., UP Sadan, Chankya Puri, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

21/11

INSPECTION REPORT

1. Name & address of the building: **U.P.Bhawan, 5, Sardar Patel Marg, New Delhi-21.**
2. Type of Occupancy : **Mixed (Business & Residential)**
3. Building comprised of : **Basement, Ground & Three upper floors**
4. Type of Case : **Renewal**
5. Details of previous NOC : **F6/DFS/MS/93/926 dated 25/05/1993**
6. Fire Safety directives Letter No. : **F6/MS/88/319 dated 18/03/1988**
7. Date of inspection : **10/12/2021**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer
from the building side : **Mr. Arjun (UPRNN)**
10. Year of Construction : **90-91**

11. Applicant's letter received through email ID-printways@gmail.com dated 26/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5	Provided	MR
	• Width of internal road	Required	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	3	Provided	MR
	b. Width of staircases			
	• Upper floors	Required	1.35m x 2 & 1.25m x 1	MR (Old Case)
	• Basements	Required	1.35m x 2 & 1.25m x 1	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	3	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Required	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Ground Floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	30	40	M/R
	• Types	ISI marked ABC/CO ₂	ABC/CO ₂	M/R
	• ISI marking	Required	Provided	M/R

11/12

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	2	2	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	900 LPM	900 LPM	MR
	➤ Head of main pump	30 m	30 m	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	75 m	75 m	MR
	➤ Standby Pump out put	900 LPM	900 LPM	MR
	➤ Standby Pump Head	30 m	30 m	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 ltr	80,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Ltr	20,000 Ltr	MR

4/13

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 flooding system in LT, HT Panel	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/93/926 dated 25/05/1993 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

A.K.
13/12/2021

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)

~~Do (S1)~~

Riv
14/12/2021

~~DLFO (S2)~~

sh
16/12

~~A.D.O. (S.J.)~~

Sir, As Approved, F.T. is added for signature.

~~Dy CFO (S2)~~

sh

M.S. Uff

A.K.
17/12/2021