

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/SZ/ 632

Dated: 21/12/2021

FIRE SAFETY CERTIFICATE

Certified that the World Wide Life Fund Building located at 172-B, Lodhi Estate, New Delhi-110003, comprised of Basement, Ground & 2 Upper Floors only, owned / occupied by World Wide Life Fund Building, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/SZ/2019/316 dated 07/02/2019. The premises was re-inspected by the officer concerned of Fire Service on 10/12/2021 in the presence of Sh. Satish Kumar (Manager Operation) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Business" with effect from 21 / 12 / 2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

Issued on 21/12/2021 at New Delhi by.


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Sh. Satish Kumar (Manager Operation), WWF-India, 172-B, Lodi Estate, New Delhi-03.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

- 2115
1. Name & address of the building: **M/s World Wide Life Fund Building, 172-B, Lodhi Estate, New Delhi-110003.**
 2. Type of Occupancy : **Business**
 3. Building comprised of : **Basement, Ground & Two upper floors**
 4. Type of Case : **Renewal**
 5. Details of previous NOC : **F6/DFS/MS/SZ/2019/316 dated 07/02/2019**
 6. Fire Safety directives Letter No. : **F6/DFS/MS/BP/87/1367 dated 25/09/1987**
 7. Date of inspection : **10/12/2021**
 8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
 9. Name and designation of Officer from the building side : **Sh. Satish Kumar (Manager Operation)**
 10. Year of Construction : **1991**
 11. Applicant's letter received through email **ID-satishk@wwfindia.net** dated 01/12/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	12m	MR
	• Gate width	Required	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	5	MR
	• Basements	3	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25m	1.24m, 1.18m, 1.14m (Spiral), 1.02m, 1.22m	MR (Old Case)
	• Basements	1.25m	1.24m, 1.02m & 1.22m	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	3	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 ACPH	Provided	MR
	• Ground Floor	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	Required	24	M/R
	• Types	ISI marked ABC/CO ₂	ABC/CO ₂	M/R
	• ISI marking	Required	Provided	M/R

(Signature)


6. First – Aid Hose Reels			
• Total numbers on each floor	2	2	MR
• Length of hose reel hose	30m	30m	MR
• Nozzle diameter	5mm	5mm	MR
7. Automatic fire detection and alarming system			
• Type of detector	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA
8. MOEFA	Required	Provided	MR
9. Public Address System	NA	NA	NA
10. Automatic Sprinkler System			
• Basement	Required	Provided	MR
• Upper Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA
11. Internal Hydrants			
• Size of riser/down- comer	NA	100 mm	NA
• Number of hydrants per floor	NA	1	NA
• Hose Box	NA	1	NA
12. Yard Hydrants			
• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA
13. Pumping Arrangements			
• Ground Level			
➤ Discharge of main pump	1800 LPM	1800 LPM	MR
➤ Head of main pump	50 m	50 m	MR
➤ Number of main pumps	1	1	MR
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Staring/Manual stopping	NA	NA	NA
➤ Pump House Access	Required	Provided	MR
• Terrace level			
➤ Discharge of pump	N/A	N/A	N/A
➤ Head of the pump	N/A	N/A	N/A
➤ Power supply	N/A	N/A	N/A
➤ Auto starting of pump	N/A	N/A	N/A
14. Captive water Storage for fire fighting			
• Underground tank capacity	50,000 ltr	50,000 ltr	MR
➤ Draw of connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	10,000 Ltr	10,000 Ltr	MR

N/17

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/SZ/2019/316 dated 07/02/2019** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 13/12/2021
 Signature of the Inspecting Officer
 Name : A.K. Jaiswal
 Designation : A.D.O. (S.J.)

~~DO (SD)~~

King
14/12/21


~~DEFO (S2)~~

h
15/12

F.T.

F.T. is added pl. A.D.O.S.J.

Dy CFO (S2)


 16/12/2021
 M.S.