



1-18
C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2021/ 387

Dated: 31 /12/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/s East Delhi Diner (EDD Hospitality LLP)** running at **First floor only F-104, V3S Mall, Laxami Nagar, Delhi-110092** building comprised of **Basement + Ground + 04 Upper floors, restaurant running on First floor only** owned/occupied by V3S Mall. The premises was inspected by the officer concerned of this department on **13/12/2021** in the presence of Mr. Kuldeep Chauhan (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group D, Restaurant running at First floor only** with effect from ~~31/12/21~~-----for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued ~~31/12/21~~-----at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

of
mu

Copy to:-

- 1 The Manager,
M/s East Delhi Diner (EDD Hospitality LLP),
First floor only F-104, V3S Mall, Laxami Nagar, Delhi-110092.
Online application ID no. 2021100523399.
- 2 The Dy. Health Officer,
EDMC Health Departement, Shahadra (South Zon), Karkardooma, Shahadara, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

7/14

INSPECTION REPORT

- | | |
|---|--|
| 1. Name & address of the building | M/s East Delhi Diner (EDD Hospitality LLP) running at First floor only F-104, V3S Mall, Laxami Nagar, Delhi-110092 |
| 2. Type of occupancy:- | Assembly Building Group-D
Basement + Ground + 04 Upper floor
Restaurant running at First floor only |
| 3. Type of case:- | New Case |
| 4. Details of previous FSC:- | N/A |
| 5. Fire safety directives No.- | NBC-part IV |
| 6. Date of inspection:- | 13/12/2021 |
| 7. Name of the inspecting officer:- | Sh. Manoj Kumar Sharma (ADO/LN) |
| 8. Name & designation of officer from the building side:- | Mr. Kuldeep Chauhan (Manager) |
| 9. Year of construction:- | 2006 |
| 10. Applicant's letter No:- | ID no. 2021100523399 |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC part-IV	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr	26 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	06 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	2 mtr., 1.5 mtr. & 1 mtr.	2 mtr., 1.5 mtr., 1.8 mtr. & 1 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	1.5 mtr.	1.5mtr.	MR
	F. Door size	1.5 mtr.	2 nos. 1.5 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	03 Nos.	05 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 nos.	01 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Heat & smoke	provided	MR
	2) Location of main panel	Control room	1 st basement	MR
	3) Location of repeater panel	Security room	Provided	MR
	4) Alternate source of power	Battery & DG set	Provided	MR
	5) Hooter's Location	Different location	Different location	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01 nos.	01 nos.	MR
	3) Hose box	01 nos.	01 nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	01 nos.	MR
	2) Hose box	N/A	01 nos.	MR
13.	Pumping Arrangement	Provided for V3S Mall		
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	60 m	60 m	MR
	c) Number of main pump	01 nos.	01 nos.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	60 m	60 m	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	60 m	60 m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	30,000 ltr.	30,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

22

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and fire fighting system is common.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

M.K. Sharma
12/12

Name :- M.K. Sharma
Designation :- ADO (LN)



Dy.CFO/NDZ

R.D. Kumar
15/12/21

CFO/NDZ

deep
10/12

12/12/21
And LN
Mur



(P.T.D.)