

G-146

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2022/NDZ/06

Dated : 05.01.2022

FIRE SAFETY CERTIFICATE

Certified that the **EMPORIO DX Guest House** located at **33**, municipal no. 7885 Arakashan Road, Pahar Ganj, New Delhi, comprised of Ground floor +5 upper floor, ground -(08 guest rooms + Reception), 1st floor to 3rd floor (10 guest rooms at each floor), 4th floor -01 guest room + 09 owner's residence and 5th floor found sealed, Total -39 guest rooms. The FSC was earlier issued to the name & style M/S SOMA Dx. Guest house by this department vide letter No.F6/DFS/MS/GH/2016/NDZ/1275 dated 12/08/16. Now, the premises was re-inspected by the officer concerned of this department on 29/12/21 in the presence of Mr. Chander and found that Gr. floor -(07 guest rooms + Reception+ office), 1st floor to 3rd floor (10 guest rooms at each floor) **4th & 5th floor not in use as per undertaking dated 29.12.2021 submitted by applicant.** The said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Gr. floor -(07 guest rooms + Reception+ office), 1st floor to 3rd floor (10 guest rooms at each floor), total 37 guest rooms up to third floor only** with effect from 05.01.2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...05.01.2022...at New Delhi by.


5/1/22

(Dr S.K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi: to ensure the occupancy as detailed and not to use any floor above third floor.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
ID NO. 2021080516962 dated 22.12.21.
3. The Manager,
**EMPORIO DX Guest House, 33, Municipal no. 7885 Arakashan Road,
Pahar Ganj, New Delhi,**

Conditions for the validity of Fire Safety Certificate

1. **This clearance/ FSC shall stand cancelled if guest house owner/occupier fails to comply all other condition mentioned in the gazette notification dated 27.05.2019 & clarification issued dated on 20.12.2021 latest by 31.03.2022.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. The owner shall not use any floor above third floor for any purpose and same shall remain closed/locked.

4746

INSPECTION REPORT

1.	Name & address of the building	M/S EMPORIO DX Guest House located at 33, municipal no. 7885, Arakashan Road, Pahar Ganj, New Delhi
2.	Type of occupancy:-	Residential Group A-1 Ground and 5 th upper floor , ground floor – (07 guest rooms + Reception + office), 1 st floor- to 3 rd floor (10 guest rooms at each floor), Total -37 guest room and an undertaking dated 29.12.21 submitted by owner/occupier regarding not to use any floor above third floor and not in as per building plan .
3	Type of case:-	Renewal
4	Details of previous FSC:-	No. F6/DFS/MS/GH/2016/NDZ/1275 dated 12/08/16.
5	Fire safety directives No.-	N/A
6	Date of inspection:-	29.12.2021
7	Name of the inspecting officer:-	Sh. Ravinder Singh (ADO/CC)
8	Name & designation of officer From the building side:-	<u>Mr. Chander</u>
9	Year of construction:-	1970
10	Applicant's letter No:-	ID NO. 2021080516962 dated 22.12.21

Old renewal

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	10 mtr	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 cms.	.99 mtr. to 1.02 mtr	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required as per G.N dated 27.05.19	Not provided	Last dt.31.03.22 of compliance extended vide order dt. 20.12.2021
	2. Pressurization	N/A	N/A	N/A

	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural/exhaust	MR
5.	Fire Extinguishers			
	1) Total numbers	15 Nos.	15 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Gr. floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Gr. floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			

21/48

	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5,000 ltr.	5,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO²			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/2016/1275 dated 12/08/16, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval up to third floor only, *mtL conditions.*

Signature of the Inspecting Officer

[Handwritten Signature]
31/01/22

Name : Ravinder Singh
Designation : ADO (CC)

[Handwritten Signature]
Do/CO

[Handwritten Signature]
31/1/22

[Handwritten Signature]
Dy. Commr

[Handwritten Signature]
31/1/22

[Handwritten Signature]
ADD/CC

As approved by Dept for kind perusal and

