



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Metro/2021/SZ/ 05

Dated: 05 / 01 /2022

**FIRE SAFETY CERTIFICATE**

Certified that “Ghitorni Metro Station of Qutab Minar-Gurgaon Corridor, New Delhi comprised of Ground + Concourse & platform floor was issued Fire Safety Certificate by this department vide letter no F6/DFS/MS/2010/1244 dated 29.04.2010. The premise was re-inspected by the officer concerned of this department on 21/12/2021 in the presence of Mr. Ashish (Fire-inspector) and found that the said metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D “Assembly Occupancy Metro railway” as above with effect from 05 / 01 /2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05 / 01 /2022 at New Delhi by

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. Mr. Vivek Srivastava, (JGM/E&M) Delhi Metro Rail Corporation, Metro Bhawan, 13, Fire Brigade Lane, New Delhi-110001.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of fire fighting system.
3. The basement shall be used strictly as per the provision of Building Bye Laws.
4. The owner/occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.”

MS  
**INSPECTION REPORT**

1. Name & address of the building: Ghitorni Metro Station, of Qutab Minar-Gurgaon Corridor, New Delhi.
2. Type of Occupancy : Assembly D-7 (Metro Station)
3. Type of Case : Renewal (Ground Level : Concourse : Platform Level)
4. Details of previous NOC : F6/DFS/MS/2010/1244 dated 29.04.2010
5. Fire Safety directives letter No : F6/DFS/MS/BP/2009/856 dated 25.03.2009
6. Date of inspection : 21.12.2021
7. Name of the Inspecting Officers : Sh. Rajesh Kumar, ADO (BCP)
8. Name and designation of officers  
from the building side : Mr. Ashish , Fire Inspector
9. Year of Construction : 2010
10. Applicant's letter No. : Gmail Dated: 09.12.2021

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	As per PWD	Provided	MR
	• Gate width	Required	Approx 06 mtr	MR
	• Width of internal road	As per NBC	6 mtr	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04nos Concourse to platform	Provided	MR
	• Basements	02 nos ground to Concourse		
	b. Width of staircases	NA	NA	NA
	• Upper Floors concourse to platform	As per NBC	PF to CC- 3.35 mtr (02 Nos) 1.90 m + 1 m escalator (02 Nos)	MR
	Basements	NA	CC- to Ground 2.35 mtr (02 Nos) + 1 mtr escalator (02 Nos)	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	2 m	2 m	MR
	f. Door Size	Required	1.9m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30ACPH	NA	NA
	• Upper floors	12ACPH	NA	NA

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	20nos	20nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ISI marked	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	04 – platform level 02 – concourse level	04 – platform level 02 – concourse level	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	45m	45m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	Required	Platform each-02 Concourse - 02	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required	Platform each-02 Concourse - 02	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	02 Nos	02 Nos	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02 Nos	02 Nos	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main Pump</li> </ul>	1800 Lpm	1800 LPM	MR
	<ul style="list-style-type: none"> <li>Head of Main pump</li> </ul>	60 mtr	60m	MR
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>Jockey Pump out put</li> </ul>	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> <li>Jockey pump heat</li> </ul>	60 m	60m	M/R
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul>	1800LPM	1800 LPM	MR
	<ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul>	60 mtr	60m	MR
	<ul style="list-style-type: none"> <li>Auto Starting/ Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			

	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	50,000ltrs	50,000ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/2010/1244 dated 29.04.2010, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*20/5/12*  
*DeFO (S)*

*29/12/12*  
*F.T.*  
*29/12*

*28/12*  
 Signature of the Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Design: ADO (BCP)  
*A DO (S/P)*