

C-68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2021/ 543

Dated 22.12.2021

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Venus International** located at **1925-27, Gali No. 10, Chuna Mandi, Pahar Ganj, New Delhi** comprised of Ground + 04 Upper floors, Ground floor (Reception + 03 guest rooms + 01 office), 1st floor to 3rd floor (04 guest rooms + 01 staff + 01 store at each floor) and Terrace floor (02 staff room + kitchen + DG Set.), total 15 guest rooms owned/occupied by Hotel Venus International was earlier granted FSC by this department vide letter no.F6/DFS/MS/GH/NDZ/2018/936 dated 07/05/18. Now, the premises was re-inspected by the officer concerned of this department on 14/12/21 in the presence of Sh. Hasim and found that the said guest house building **having given an affidavit dated 28.11.2019 regarding not to use any floor above third floor** has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Ground floor (Reception + 03 guest rooms + 01 office), 1st floor to 3rd floor (04 guest rooms + 01 staff + 01 store at each floor) total 15 guest rooms up to third floor only**, with effect from....22.12.21.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued22.12.21.....at New Delhi by.


21/12/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner North, MCD, Civic Centre, New Delhi. to ensure the occupancy in the building as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. online id no 2021090820705 dated 08.09.21 @ e-mail id no.1591shiv@gmail.com dated 23.11.2021.
3. The Manager,
Hotel Venus International at 1925-27, Gali No. 10, Chuna Mandi, Pahar Ganj,
New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N125
INSPECTION REPORT

1. Name & address of the building Hotel Venus International at 1925-27, Gali No. 10, Chuna Mandi, Pahar Ganj, New Delhi Residential, Sub Division-A-1
2. Type of occupancy:-
Gr. + 03 Upper floors (total 15 Guest rooms)
Ground floor (Reception + 03 guest rooms + 01 office),
1st floor to 3rd floor (04 guest rooms + 01 staff + 01 store at each floor) and Terrace floor (02 staff room + kitchen + DG Set.) **an affidavit given by owner dated 28.11.2019 regarding not to use any floor above third floor.**
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/NDZ/2018/936 dated 07/05/18.
5. Fire safety directives No.- N/A
6. Date of inspection:- 14/12/21
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Sh. Hasim
9. Year of construction:- 2001
10. Applicant's letter No:- online id no 2021090820705 dated 08.09.21
@ e-mail id no.1591shiv@gmail.com dated 23.11.2021.
Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement/ Existing fire safety arrangements | Provided at site | Remarks MR/NMR |
|-----------|---|--|------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | N/A | 06 mtr. | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 01 Nos. | 01 Nos. | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | 0.80 mtr. | 1.20 mtr. | MR |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | 01 | 01 | MR |
| | E. Width of corridor | 1 mtr. | 1 mtr. | MR |
| | F. Door size | 1 mtr. | 1 mtr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 ACPH | N/A | N/A |
| | 2) Upper floors | 12 a/c per hour | Provided | MR |

M/25

| | | | | |
|------------|---|--------------|-----------|-----|
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 10 Nos. | 12 Nos. | MR |
| | 2) Types | ABC & CO2 | ABC & CO2 | MR |
| | 3) ISI marking | Required | Provided | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | 01 | Provided | MR |
| | 2) Length of hose reel hose | 30 mtr. | Provided | MR |
| | 3) Nozzle diameter | 05 mm | Provided | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors CO Type | Required | Provided | MR |
| | 2) Location of main panel | Ground floor | Provided | MR |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | Required | Provided | MR |
| | 5) Hooter's Location | Each floor | Provided | MR |
| 8. | MOEFA | N/A | Provided | N/A |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump output | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 450 LPM | 450 LPM | MR |
| | b) Head of pump | 30 mtr. | 30 mtr. | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | Provided | MR |

12/26

| | | | | |
|-----|---|-----------|--------------------|-----|
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 2500 ltr. | 2500 ltr. Old Case | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. No. F6/DFS/MS/GH/NDZ/2018/936 dated 07/05/18, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval up to third floor only,

Signature of the Inspecting Officer

Name: Ravinder Singh
Designation: ADO (CC)

[Handwritten Signature]

25/12/21

[Handwritten Signature]

[Handwritten Signature]
20/12/21

[Handwritten Signature]

As approved by input up for kind perused and separate P/plan

[Handwritten Signature]
21/12/21

[Handwritten Signature]

[Handwritten Signature]
21/12/21

FSC uploaded
22/12 Sameer

