

e 31

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/SZ/ 17

Dated: 05/01/2022

FIRE SAFETY CERTIFICATE

Certified that the Kendriya Vidyalaya located at Andrews Ganj, New Delhi-110024, comprised of 3 blocks – Sr. Sec. block – Ground + 02 Uppers & Primary Floor, Sec. Block-Ground + 02 Upper Floors & Primary Block – Ground floor having 48 class rooms & 12 other rooms, owned / occupied by Kendriya Vidyalaya, was issued Fire Safety Certificate by this department Vide letter No. F6/DFS/MS/School/2014/SZ/21 dated 07/01/2014. The premises was re-inspected by the officer concerned of this department on 27/12/2021 in the presence of Mr. R.K Sharma (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class “Educational” (Group-B) with effect from 05/01/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 05/01/2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. Principal, Kendriya Vidyalaya, Andrews Ganj, New Delhi-110024.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

21/-16
INSPECTION REPORT

1. Name & address of the building: Kendriya Vidyalaya, Andrews Ganj, New Delhi- 110024.
2. Type of Occupancy : Educational Building "Group-B"(school)
3. Building Comprised of : Ground + Two Upper Floor
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2014/SZ/21 dated 07/01/2014
6. Fire Safety directives Letter No. : DOE Circular no. 3298 to 3398 Dated 01/03/2011
7. Date of inspection : 27/12/2021
8. Name of the Inspecting Officer : A.D.O. (S.J.)
9. Name and designation of Officer from the building side : Mr. R.K Sharma (Principal)
10. Year of Construction : 1968
11. Applicant's letter received through email kd-kvandrewsganj1404@gmail.com dated 13/08/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	10m	MR
	• Gate width	5m	3 nos 5m each	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	4	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m	1.50m x 3 nos each, 1.30m-1 no.	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	Provided	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	45	45	MR
	• Types	ABC /Co ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR



6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

8.	MOEFA	Required	Provided	MR
----	-------	----------	----------	----

9.	Public Address System	Required	Provided	MR
----	-----------------------	----------	----------	----

10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA

12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	required	Provided	MR

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr	Provided	MR

N/18

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA


Note:- 1. Shortcomings issued by this department vide letter No. F6/DFS/MS/School/2020/SZ/461 dated 11/05/2020 have been complied.

2. General requirements for schools as per Director of Education circular dated 01/03/2011.




1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2014/SZ/21 dated 07/01/2014 renewal under rule 35 of the Delhi Fire Service rules 2010.


 29/12/2021

Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : D.O.


 29/12/21