

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 1055

Dated: 22 / 12 / 2021

FIRE SAFETY CERTIFICATE

Certified that **Saraswati Bal Mandir**, located at A Block, Amar Colony, Lajpat Nagar-IV, New Delhi-110024 Comprised of Ground plus Two upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2244 Dated 05/10/2018. The said premise was re-inspected by officer concerned of this department on 10/12/2021 in presence of Mr. Ashok Kumar Mittal and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service, 2010 and the building is fit for occupancy class "**Educational Building Group – B**" with effect from 22/12 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 22 / 12 -2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, Saraswati BAL Mandir, A Block, Amar Colony, Lajpat Nagar-IV, New Delhi-110024.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Saraswati Bal Mandir, A Block, Amar Colony, Lajpat Nagar-IV, New Delhi-110022		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 02 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/2244 Dated 05/10/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2002/404 dated 11-03-2002		
7	Date of Inspection	10/12/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ashok Kumar Mittal		
10	Year of construction	2002-03		
11	Applicant letter No.	Gmail dated 29/09/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	06 mtr	MR
	• Gate width	Required	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	01 No's	02 No's	M/R
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floor	i 50m/ o 75m	i 50 mtr	M/R
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 No's	MR
	e) Width of corridor	1.50 m	2.15 m	MR
	f) Door size	01 m	1.10 m	M/R
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers		12 No's	MR
	• Types	ISI mark	ABC-06 & CO2 -06	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose reel	02 No's	M/R
	• Length of hose-reel hose.	30 M	Provided	M/R
	• Nozzle Diameter	5MM	Provided	M/R
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	ABC type fire Extinguisher near elec. penal		MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2244 Dated 05/10/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

JK
13/12

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD) *JK*
14/12/21 F.T.,

DFO(2) *JK*

ADO (BCP)

As approved, f.T. letter is put up for your signature pl

JK
16/12

DFO(2) *JK*

ANANT KARY

M.S.U