

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Assembly/UG/2022/SZ/ 14

Dated: 12/01/2022

FIRE SAFETY CERTIFICATE

Certified that the **Ashram Underground Metro Station of Line-07**, comprising of Five Levels (Undercroft, Platform, Concourse, & Ground Level) was granted Fire Safety Certificate by this department vide letter no F6/DFS/MS/Assembly.(UG)/SZ/2018/2611 dated 04/12/2018. The premise was re-inspected by the officer concerned of this department on 02-01-2022 in the presence of Mr. Sanyam Jain (AM/Fire) and found that the said metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Group D-7 Assembly Building**" as above with effect from 12/01/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/01/2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. Mr. Sanyam Jain (AM/Fire) Delhi Metro Rail Corporation, Metro Bhawan, Fire Brigade Lane, New Delhi-110001.
2. The Chief Project Manager-8,/Line-7, Ground floor, Mayur Vihar phase-1, Metro Station, Delhi 110091

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of fire fighting system.
3. The basement shall be used strictly as per the provision of Building Bye Laws.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Ashram Underground Metro Station of Line 7		
2	Type of Occupancy	Assembly (D-7)		
3	Building Comprised of	Five level (Undercroft, platform, Concourse, Mezzanine + Ground Floor)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Assembly.(UG)/SZ/2018/2611 dated 04/12/2018		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/329 dated 18/10/2018		
7	Date of Inspection	02-01-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sanyam Jain (AM/Fire)		
10	Year of construction	2018		
11	Applicant letter No.	Gmail Dated 06/12/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	12 mtr.	MR
	• Gate width	NA	6 m	NA
	• Width of internal road	Approachable	About on road	MR
2	Number, width, type & arrangements of exits			
	a. Number of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	Undercroft to platform -2 No Platform to CC-46 No's + 02 Escalator Platform to mezzanine -1 No CC to Mezzanine-2 No + 02 Escalator CC to Ground- 01 No's Mezzanine to Ground- 03 No + 02 Escalator	Provided	MR (50 % capacity of escalators is counted for evacuation in NFPA)
	b. Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	1.12m & 0.91m (maintenance Staircase)	1 m & 1 m 3.55 m, 3.55m, 1.95m & 1m + 1m x 2 No's 1.27 m 3.8m & 3.6m +1m x 02 no's 1.1m 5.92m, 4.34m & 3.62m + 1m x 2 No's	MR
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required in Fireman staircase & emergency staircase	Provided	MR
	d. No. of continuous staircase to terrace	Ancillary building	Provided	MR
	e. Width of corridor	0.91 m	1 mtr	MR
	f. Door size	0.91 m	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	30 minute & 3 hours	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	Required	Provided	MR
4	Smoke Management system.			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers		98 Nos	MR
	• Types	ISI Marked	ABC , & W.CO ₂ ,	MR

N/12

	<ul style="list-style-type: none"> ISI Marking 		Co2	
			Provided	MR
6	First Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor. 	02 No in ancillary building, 1 no in chillar plant room, 06 nos at mezzanine, 05 nos at concourse, 04 nos at platform	Provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	36m	36m	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	6mm	6mm	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Smoke & Heat	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Concourse level	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided DG Set	MR
	<ul style="list-style-type: none"> Hooter's location 	Required	Provided at all levels	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required in following rooms:- mess, store, Security, Locker	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	02 No in ancillary building, 1 no in chillar plant room, 06 nos at mezzanine, 05 nos at concourse, 04 nos at platform	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	02 No in ancillary building, 1 no in chillar plant room, 06 nos at mezzanine, 05 nos at concourse, 04 nos at platform	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	01 No's Required	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	01 No in ancillary building, 01 Nos at each tunnel portal	Provided	MR
13	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	2839 LPM	Provided	MR
	➤ Head of main pump.	88m for hydrant & 75m for sprinkler	Provided	MR
	➤ Number of main pumps.	Two	Provided	MR
	➤ Jockey Pump output.	2 x 189 LPM	Provided	MR
	➤ Jockey Pump head.	88m for hydrant & 75m for sprinkler	Provided	MR
	➤ Standby Pump output.	2 x 2839 LPM (electric)	Provided	MR
	➤ Standby Pump head.	88m for hydrant & 75m for sprinkler	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	b) Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A

N/13

14	Captive water storage for Fire Fighting. <ul style="list-style-type: none"> • Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		2,00,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. <ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area <ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room. <ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required in SCR	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection System for the Protection of Special Risk, if any :	Clean agent flooding system for electrical panels & Transformer		MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Assembly.(UG)/SZ/2018/2611 dated 04/12/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
31/1/2022

Signature of Inspecting Officer
 Name: Rajesh Kumar
 Design: ADO (BCP)

~~DO (SD)~~

RMP
04/01

F.T.

DFG/SZ

[Signature]

A D O (BCP)

As approved, f.t. letter is put up for your signature P

RK
7/1/2022

Dy C/O/SZ

M.S. Col