

C/S9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/ 05

Dated 12/01/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Sagar Ratna (A Unit of Sagar Ratna Restaurant Pvt Ltd)** located at Ground & First Floor, C-2, Malviya Nagar, New Delhi 110017 comprised of Basement, Ground Plus Four Upper Floors, 4th floor (not in use), (Restt. running at ground & First floor of the building) owned/occupied by Mr. Udaya Kumar was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/SZ/2018/2112 dated 14/09/2018. The restaurant premise was re-inspected by the officer concerned of this department on 03/01/2022 in the presence of Sh. Manish Kumar (Cashier) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 12/01/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12 / 01 /2022 at New Delhi by


**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Joint C.P (Lic) First Floor, PS Defence Colony, New Delhi – 110049.
2. The Dy. Health Officer, Public Health Department, South MCD, Green Park, New Delhi 110016 (Ref. MHA Portal Id 2021121728762 dated 20-12-2021)
3. M/s Sagar Ratna (A Unit of Sagar Ratna Restaurant Pvt Ltd) located at Ground & First Floor, C-2, Malviya Nagar, New Delhi 110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. **4th floor of the building is not allowed and under lock & key (not in use) with management (undertaking).**

M/13

INSPECTION REPORT

1	Name & Address of the Building	M/s Sagar Ratna Restaurant at C-2, GF & FF, Malviya Nagar, Main Market, New Delhi 110017
2	Type of Occupancy	Assembly 'Group-D'
3	Building comprised of	Basement, Ground + Fourth Upper Floor, 4 th Floor
4	Type of Case	Sealed by owner
5	Details of Previous NOC	Renewal
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/SZ/2018/2112 dated 14/09/2018
7	Fire Safety Directives Letter No	Nil
8	Date of Inspection	03.01.2022
9	Name of the Inspecting Officers	Rajesh Kumar/ ADO (BCP)
10	Name & Designation of Officers from the building side	Sh. Manish Kumar (Cashier)
11	Year of construction/ date of conversion	2009, restt. running at GF & FF of the building
11	Applicant letter No.	MHA Portal Id 2021121728762 dated 20-12-2021

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks
1	Access to Building.			
	• Road width	06 m	Provided	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 no's	MR
	• Basement floor	-NA-	NA	-NA-
	b. Width of Staircase			
	• Upper floors	1.14 m & 1 m	1.14 m & 1 m	MR (Old Case)
	• Basement floor	-NA-	NA	-NA-
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	01	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	02 nos exit	GF-1.09, 1.05 & 1 m FF- 1.10 & 1 mtr	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fan Provided	MR
5	Fire Extinguishers.			
	• Total numbers	08 Nos	Provided	MR
	• Types	ABC / CO2	ABC-04& Co2-04	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat/Smoke	MR
	• Location of Main Panel	Required	Ground floor	MR

2/14

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooper's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Each floor	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	NA	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		01	provided	MR
		01	provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		N/A	-NA-	-NA-
		N/A	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	Boosting pump	450 & 180 LPM	MR
		40 m	38mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 350 dated 18/08/2021. 4th floor of the building is not allowed and under lock & key (not in use) with management (undertaking).

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2018/2112 dated 14/09/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Rajesh Kumar
31/10/22

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

~~DO (SD)~~

Rajesh Kumar
04/01

~~DFO (P2) F.T.~~
[Signature]

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl

Rajesh Kumar
31/10/22

~~DFO (P2)~~
[Signature]
M.S. Ch...