

C-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No. F6/DFS/MS/School/WZ/2021/29

Dated: 12/01/2022

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya No. 01, (ID-1514012)** located at **Khayala (New Building) New Delhi-110018**, comprised of Ground Floor + 03 Upper Floors (**Two Blocks & One MP Hall**), owned/occupied by **Sarvodaya Kanya Vidyalaya No.1** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and verified by the officer concerned of this department on 30/12/2021 in the presence of Sh. Nitin Panwar (Project Manager) and found that the building / premises is fit for the occupancy class **“Educational” Group B** with effect from 12/01/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditioned mentioned below.

Issued on 12/01/2022 at New Delhi.


(Atul Garg)
Director

Delhi Fire Service

Copy to:

1. The Principal, Govt. Sarvodaya Bal Vidyalaya Bal (ID-1514110) located at Khayala (New Building) New Delhi-110018 School.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

277

1. Name & address of the building: Sarvodaya Kanya Vidyalaya No.01, Khayla (New Building) New Delhi - 110018 (School ID-1514012)
2. Type of Occupancy : Educational (Two Blocks, Ground + 03 Upper Floors in Each Block + one MP Hall)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 30/12/2021
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer from the building side : Sh. Nitin Panwar (Project incharge)
9. Year of Construction : 2021
10. Applicant's letter No. : 54 (SPS School)/PWD Edu. Sub- Divn M1-1(N)/2021-22/73 dated 20/12/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL-16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2 X 1.20 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

SPS

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NR	Provided	NR
	• Number of hydrants per floor	NR	Provided	NR
	• Hose Box	NR	Provided	NR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Liters	Provided	MR
15.	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fire man's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/MN/2021/572 dated 18/10/2021 & F6/DFS/MS/School/MN/2021/635 dated 09/12/2021 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

~~Do (west)~~

371/ADO/MN
04/01/2022

~~DO~~
05/01/22

~~SA~~
04/01/2022
Sarabjeet Singh
ADO (MN)

D.O. (WEST)/342
DATED... 5/1/2022

$\frac{DCFB(WZ) - E/L}{DCFB(1/2)}$

C.F.O. (D. off)

~~DO~~
7/1/2022
Anur/MN

Sin P. T is not up for your personal signature please

~~SA~~
11/01/2022