

C-8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2022/ 47

Dated: 17/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Govt. Boys Secondary School located at New Rohtak Road, 22- Dev Nagar, New Delhi- 110005** is comprised of ground floor only was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2018/2056 dated 07.09.2018. The school building was re-inspected by the officer concerned of this department on 05.01.2022 in presence of Sh. Krishan Pal Kardam, HOS of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class **“Educational”** with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 17/01/2022 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Boys Secondary School, New Rohtak Road, 22- Dev Nagar, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

**INSPECTION REPORT**

1. Name & address of the building : Govt. Boys Secondary School, New Rohtak Road, 22- Dev Nagar, New Delhi- 110005
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2018/2056 dated 07.09.2018
5. Fire Safety directives letter No : Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011
6. Date of inspection : 05.01.2022
7. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Sh. Krishan Pal Kardam, (HOS)
9. Year of Construction : Before 2010
10. Applicant's letter No. : Online email id [hos2128006@gmail.com](mailto:hos2128006@gmail.com) dated 23.12.2021

Govt. Boys. Secondary School, New Rohtak Road, 22- Dev Nagar, New Delhi- 110005 is comprised of ground floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per D.o.E circular dated 01-03-2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	Provide	MR
	• Gate width	4.5 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A

5	<b>Fire Extinguishers</b>			
	• Total numbers	05 nos	Provided	MR
	• Types	ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	----	N/A	N/A
	• Length of hose reel hose	30 m	N/A	N/A
	• Nozzle diameter	5 mm	N/A	N/A
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	---	-----	-----
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A

*BB*



14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No F6/DFS/MS/School/SZ/2018/2056 dated 07.09.2018, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Accordingly, DFA is put up for approval & signature please.

*[Handwritten Signature]* 6/11/22

(P.V. Rathee)  
Asstt. Div. Officer (SRD)

*D.O. (SW)*

*[Handwritten Signature]*  
07/10/2022

*F.T.*

*Dy chd (S2)*

*[Handwritten Signature]*

*AMO (GAD)*