

REGARDING RENEW OF FIRE SAFETY CERTIFICATE...

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/School/2022/NDZ/ 36

Dated: 14/01/22

FIRE SAFETY CERTIFICATE


Certified that the Green Garden Public School at 287, Main Road, Brahmpuri, Ghonda, Delhi-110053, comprised of ground plus two upper floors (School is running at ground plus first floor) owned/occupied by Green Garden Public School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1420 dated 18/06/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 04/01/2021 in the presence of Sh. Bishamber Singh Tomer, Manager and that the school building is fit for occupancy class "B" 'Educational Building' for ground plus first floor with effect from 14.01.22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....14/01/22..... at New Delhi by

Note:- This Fire Safety Certificate does not cover second floor of the building.


14/1/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

g/c 

To,

The Manager,
Green Garden Public School,
287, Main Road, Brahmpuri,
Ghonda, Delhi-110053

Copy:-

The Director of Education,
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The manager of the school has submitted an undertaking regarding closure of school at second floor since 2016 due to shortage of students. Also in future if the school authorities would start classes at second floor they will seek the permission from this department.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Green Garden Public School, 287, Main Road, Brahmpuri, Ghonda, Delhi-110053
2. Building is comprised of : G+2 (School is running at ground plus first floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/1420 dated- 18/06/2018
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dt- 01/03/2011
7. Date of Inspection : 04/01/2022
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Bishamber Singh Tomar, Manager
10. Year of Construction : 1990
11. Applicant's letter No. : 10/200 dated- 04/01/2022

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 m	10 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	1 no.	1 no.	MR(accepted earlier)
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1 m	1 m	MR(accepted earlier)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 no.	1 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR


06	First-aid-Hose Reels.			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/12

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Kindly peruse the undertaking placed at C/16 in which the manager of the school has submitted that no classes are being conducted at second floor since 2016 due to shortage of students. Further if the authorities will start school at second floor, they will intimate and seek permission from this department. The competent authority has already accepted the undertaking earlier at the time of issuance of FSC dated 18/06/2018.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as indicated above & undertaking given by school manager, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.


 (Nagender Singh)
 ADO (Shahdara)


Dy. CFO (NDZ)


 6/11/22



ADO (Shahdara)

F.T. letter is placed for signature please.


 (Nagender Singh)
 ADO (Shahdara)

Dy. CFO (NDZ)


 14/11/22

SMS