

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/48

Dated: 17/01/2022

FIRE SAFETY CERTIFICATE

Certified that **Kendriya Vidyalaya** located at **Sec-VIII, R.K. Puram, New Delhi-110022**, comprised of two blocks, ground plus two upper floors and ground plus one upper floor both block are interconnect with each other was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2417 Dt. 26-10-2018. The premises was re-inspected by officer concerned of this department on 06/01/2022 in presence of Mrs. Mamta Shekher (Principal) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from 17/01/2022 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 17/01/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, Kendriya Vidyalaya at Sec-VIII, R.K. Puram, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certi

INSPECTION REPORT				
1	Name & Address of the Building	Kendriya Vidyalaya located at Sec-VIII, R.K. Puram, New Delhi-110022		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	02 blocks, ground plus two upper floors and ground plus one upper floor both block are interconnect		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/2417 Dt. 26-10-2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	06-01-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Mamta Shekhar (Principal)		
10	Year of construction	1977		
11	Applicant letter No.	Gmail dated 09/12/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	07 mtr	MR
	• Gate width	4 m & 2.5 m	4 m & 2.5 m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 No Required	01 Nos for G+1 02 Nos for G+2	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50m / 0.75m	1.40 m each	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 Nos	MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	30 Nos	30 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	02 No for G+2 01 no for G+1	Provided	MR

	<ul style="list-style-type: none"> Length of hose-reel hose. Nozzle Diameter 	30m 5mm	Provided Provided	MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm 02 No 02 No	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 LPM 40m Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 LPM x 2 40 M x 2 Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA- -NA- Required -NA- 10,000 Ltr	-NA- -NA- Provided -NA- Provided	-NA- -NA- MR -NA- MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18	Refuge Area			

	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2417 Dt. 26-10-2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

AK
10/11/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

AK
10/11/22

E.A.

Dy C/O (SZ)



ADDO (BCP)

As approved, F.T. letter is put up for your signature P.I.

AK
14/11/2022

Dy C/O (SZ)



M.S. Cell