

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C-32

No: F6/DFS/MS/School/WZ/2021 / 1037


Dated: 21/12/2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-ed. Sr. Sec. School**, located at **Raghubir Nagar J.J. Colony (School ID 1515019) New Delhi- 110027** comprised of 03 blocks Ground Plus + 1 upper floor only was issued FSC vide letter no. F6/DFS/MS/School/2019/99 dated 15/01/2019. The premises was re-inspected by the officer concerned by this department on 07/12/2021 in the presence of Sh Arvind (PET) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention & fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Directorate of education and found that the building/premises is fit for occupancy class "Educational" Group B with effect from 21/12/2021 for a period of three years subject to compliance of the conditions mentioned overleaf:-

Issued on 21/12/2021 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service


20/12/2021

Copy to:

1. The Principal, Govt. Co-ed. Sr. Sec. School,
Raghubir Nagar J.J. Colony,
New Delhi- 110027.
2. Directorate of Education, Old Sectt. Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed. Sec. School, located at, Raghbir, Nagar J.J. Colony (School. ID 1515019) New Delhi-110027.
2. Type of Occupancy : Education (3 Blocks of Ground + 1 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/D/S/MS/School/2019/99 dated 15/01/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 07/12/2021
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Arvind (PET)
9. Year of Construction : 2011 (as per previous inspection report dtd.-21/12/2018)
10. Applicant's letter No. : Email dated 25/11/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dtd. 01/03/2011/As per prev. ins. Report dtd.-21/12/2018	Provided at site	Remarks MR/NMR									
1	Access to building												
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>Accessible</td> <td>6m Provided</td> <td>MR</td> </tr> <tr> <td>Accessible</td> <td>580cm Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible	6m Provided	MR	Accessible	580cm Provided	MR	NA	NA	NA		
Accessible	6m Provided	MR											
Accessible	580cm Provided	MR											
NA	NA	NA											
2	Number, Width, Type & Arrangement of Exits												
	a. Number of staircases												
	<ul style="list-style-type: none"> • Upper Floors • Basements 	7	A Block = 2, B Block = 2 & C Block = 3										
	b. Width of staircases												
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA									
	c. Protection of exits												
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	1.5 m	A Block = 143 cm, 145 cms B Block = 138, 146cm Iran Stair C Block = 153cm, 154cm, 155 cm	MR Being Old Case									
	e. No. of continuous staircases to terrace	NA	NA	NA									
	f. Width of Corridor	NA	NA	NA									
	g. Door Size	1.5 m	A Block = 154 cm, B Block 175 cm C Block = 175 cm	MR Being Old Case									
3	Compartmentation.												
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA									
4	Smoke Management System.												
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA									
5	Fire Extinguishers												
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	13 nos. CO ₂ , ABC type ISI marked	25 Provided Provided Provided	MR MR MR									

N-17

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NR	NR	NR
	• Length of hose reel hose	NR	NR	NR
	• Nozzle diameter	NR	NR	NR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.			
		NA	NA	NA

X

8/4


16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The Fire Protection System provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rule the NOC issued vide letter no.F6/DFS/MS/School/2019/99 dated 15/01/2019. Renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

339/ADO/MN
10/12/2021

~~D.O. (West)~~


10/12/2021

Signature of the Inspecting Office
Name: Sarbjeet Singh
Designation: ADO (MN)

D.O. (WEST)/316
DATED 13/12/2021

~~D.O. (West)~~
13/12/2021

~~D.O. (W2)~~


15/12/2021

~~ADO (MN)~~

Sir, F.T is put up for your perusal & Signature
Please.

~~D.O. (W2)~~

20/12/2021


20/12/2021

msf_ell