

C-38

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI



No.F.6/DFS/MS/WZ/2022/ 54

Dated: 20/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **North Delhi Public School** Located at, **BP- Block, Shalimar Bagh, Delhi – 110088**, comprised of **BL-1= Ground Floor & BL-2= Ground + 2 Upper Floor + Some Rooms at terrace are sealed by bricks** was issued FSC vide Letter No. F6/DFS/MS/WZ/2018/2743 dated-24/12/2018. The premises was re-inspected by the officer concerned of this department on 18/01/2022 in the presence of Sh. Parveen Kesar (Manager) and found that the premises /building have deemed complied with the fire prevention and fire safety arrangements in accordance DOE Circular 262–362 Dated 17-01-2005, and that the premises is fit for occupancy class “Educational” Group B, with effect from 20/01/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/01/22 at New Delhi by.

  
(Sunil Chaudhary)  
Dy.Chief Fire Officer  
(West-Zone)  


Copy to:

1. The Principal, North Delhi Public School, BP- Block, Shalimar Bagh, Delhi –110088.
2. Directorate of Education Old Secretariat Delhi – 110054.
3. The Commissioner, Civil line Zone, North MCD, Rajpur Road, Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. **Rooms at terrace shall be kept closed / sealed as seen during the inspection.**
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

1. Name & address of the building: **North Delhi Public School** Located at, **BP- Block, Shalimar Bagh, Delhi – 110088.**
2. Type of Occupancy : Educational (BL-1= Ground Floor & BL-2= Ground + 2 Upper Floor + **Some Rooms at terrace are sealed by bricks**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2018/2743 Dated-24.12.2018
5. Fire Safety directives Letter No.: DOE Cir. No.262-362 dated 17-01-2005
6. Date of inspection :18.01.2022
7. Name of the Inspecting Officer : S P Bhardwaj, Divisional Officer
8. Name and designation of Officer  
from the building side : Sh. Parveen Kesar (Manager)
9. Year of Construction : 1996
10. Applicant's letter No. :JMPS/18-09-10 Dated-11/09/18

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir.No.262-362 dated 17-01-05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	8m Provided	MR
	• Gate width	Accessible	5.4 m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	119cm & 122cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1mtr	Varies from 91cm to 1m	MR (Old Case)



M/A

and discharge  
read of m  
Number of  
Jockey pu  
Jockey pu  
St

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 nos.	10 Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	NA
10.	Automatic Sprinkler System			MR
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 m.m	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	4	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			

- Ground Level
- Discharge of main pump
- Head of main pump
- Number of main pumps
- Jockey pump out put
- Standby Pump head
- Standby Pump out put
- Standby Pump Head
- Auto Starting/Manual stopping
- Pump House Access
- Terrace level
- Discharge of pump
  
- Head of the pump
- Power supply
- Auto starting of pump

NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	Provided 180 LPM	NA
40 mtrs.	40 mtrs.	MR
NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA
450 lpm & 220 lpm	450 lpm & 220 lpm	MR
40Mtr	Provided	MR
Required	Provided	MR
Required	Provided	MR

4. Captive water Storage for fire fighting:

• Under ground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	Provided	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	5,000Ltrs	Provided	MR
5. Exit Signage	Required	Provided	MR
6. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
7. Standby power supply	NA	NA	NA
8. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
9. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
10. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

*[Handwritten signature]*

M/11

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per DOE Circular dated 17.01.2005, renewal of FSC issued vide letter no. F6/DFS/MS/WZ/2018/2743 dated 24.12.2018, is recommended under rule 35 of the Delhi Fire Service Rules 2010.

*[Signature]*  
Signature of the Inspecting Officer  
Designation: Divisional Officer

Do/west Boff      F.T.  
Defog w/z      *[Signature]*

D.O. (S.P.B.)

F.T. is put up for signature

Defog w/z  
*[Signature]*  
29/11  
MS, cell

*[Signature]*  
29/11/22