

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/GH/SZ/2022/ 54

Dated: 25/1/22

FIRE SAFETY CERTIFICATE

Certified that M/s. Hotel Taj Princess located at 15A/25, W.E.A, Karol Bagh, New Delhi- 110005 was granted FSC for building comprised of basement, ground plus five upper floors, using basement as hall/storage, ground floor as reception, office, lobby & 01 guest room, first, second & third floor each having 08 guest rooms respectively, fourth floor having 05 rooms and 01 hall for personal use (total 25 guest rooms), fifth floor is sealed by the owner, by this department vide letter No. F6/DFS/MS/GH/SZ/2018/1642 dated 16.07.2018. The premises was re-inspected by the officer concerned of this department on 11.01.2022 in presence of Sh. Sandeep Narula, Leaser of the guest house, and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for basement (incidental storage), ground floor (reception, office, lobby & 01 guest room), first, second and third floor each having 08 guest rooms respectively (total 25 guest rooms only) with effect from 25/1/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 25/1/22 at New Delhi by.

(Sunil Chaudhary)

Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Following Fire Safety Directives must be adhered to: -

1. The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/3618-37 dated 20.12.2021 in respect of existing building (copy enclosed) shall be implemented by 31.03.2022 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void
2. No occupancy above third floor & basement as storage purpose, shall be adhered by Owner/Occupier
3. All the means of escape shall be kept free of all type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
7. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
8. All comments / directions of licensing department shall always be permitted and followed.

Continuous.....

9. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
10. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
11. Basement shall be used as per BBL.
12. No temporary shed is allowed on terrace.
13. The Fire Safety Certificate is only for Guest Rooms.

## INSPECTION REPORT

1. Name & address of the building : M/s. Hotel Taj Princess, 15A/25, W.E.A, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2018/1642 dated 16.07.2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 11.01.2022
7. Name of the Inspecting Officers : P.V. Rathee, Asst. Divisional Officer (SRD)
8. Name and designation of officers from the building side : Sh. Sandeep Narula, Leaser
9. Year of Construction : 1998
10. Applicant's letter No. : Online Application no. 2022010300100 dated 07.01.2022

The said guest house is comprised of basement, ground plus five upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 16.07.2018	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	Required	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	Old Case	01	MR being old case
	• Basements	Old Case	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	Old case	1.31 mts	MR being old case
	• Basements	Old case	1.42 mts each	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 31.03.2022
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	1.20 mts	MR
	h. Door Size	Old case	0.80 mts	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 31.03.2022
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Not Provided	date of compliance has been extended up to 31.03.2022
5	<b>Fire Extinguishers</b>			
	• Total numbers	15	Provided	MR
	• Types	CO <sub>2</sub> , ABC, WCO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Carbon Monoxide	Not Provided	date of compliance has been extended up to 31.03.2022
	• Location of Main Panel	Required	Not Provided	date of compliance has been extended up to 31.03.2022
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	D.G. set 65 KVA	MR
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	Provided	---
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	75 mm	---
	• Number of hydrants per floor	N/A	01 No.	---
	• Hose Box	N/A	01 No.	---
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM x 02 Nos.	Provided	MR
	➤ Head of the pump	30 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 lts	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			

N/35

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/3618-37 dated 20.12.2021 in respect of existing building (copy enclosed) shall be implemented by 31.03.2022 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void. Undertaking given by owner/occupier placed at C-99.

If agree, FSC may be issued upto 3rd floor only as per BBL – Clause 7.31.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/SZ/2018/1642 dated 16.07.2018, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

D.O. (SW)

17/01/2022

Dy CFO (S2)

AAAS PC

ET

14/1/22

Signature of the Inspecting Officer  
P.V. Rathee  
Asstt. Div. Officer (SRD)