

C-18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2022/ 12

Dated : 21/1/22

**FIRE SAFETY CERTIFICATE**

Certified that the restaurant M/S Lavanya Lifestyles located at Ground floor only G-9, ground floor, Outer Circle, Connaught Place New Delhi of a building comprises of Ground + Mezzanine + 02 Upper floor but the restaurant running at ground and store at mezzanine floor. The FSC was earlier issued to said premises by this department in the name & style M/S My Govindas (A Shubhdharmas Hospitality Unit), vide letter No.F6/DFS/MS/EH/NDZ/2018/1985 dated 14/08/18. Now, the premises was re-inspected by the officers concerned of this department on 06/01/22 in the presence of Mr Hitesh ( manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group-D of Sub-Division D-5, Restaurant at Ground floor & Mezzanine floor for storage only** with effect from 21/1/22 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/1/22 at New Delhi by.

  
21/1/22

**(Dr. S.K.Tomar )**

Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ID No. Id No. 2021112527137 dated 20/12/2021.
2. The Executive Engineer , NDMC , Palika Kendra New Delhi.
3. M/S Lavanya Lifestyles at G-9, Ground and Mezzanine floor, Outer Circle, Connaught Place New Delhi.

**Condition for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for restaurant at ground floor only.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building M/S Lavanya Lifestyles  
At G-9, Ground floor, outer circle Connaught Place, New Delhi.
2. Type of occupancy:-  
Assembly Building Group-D  
Gr. + Mezzanine + 02 Upper floors, Restaurant running at Ground floor & Mezzanine floor for storage.
3. Type of case:-  
Renewal
4. Details of previous FSC:-  
F6/DFS/MS/EH/NDZ/2018/1895 dated 14.08.18
5. Fire safety directives No.-  
N/A
6. Date of inspection:-  
06/01/22
7. Name of the inspecting officer:-  
Sh. Rajinder Atwal (DO/CD)  
Sh. Ravinder Singh ( ADO /CC)
8. Name & designation of officer  
From the building side:-  
Sh. Hitesh (Manager)
9. Year of construction:-  
Old Heritage
10. Applicant's letter No:-  
Id No. 2021112527137 dated 20/12/2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06mtr	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size (Main Exit)	2 .0 mtr.	2 .0 & 1.0 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	04 Nos.	04 Nos.	MR

N/A

	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR

	d) Over head tank capacity ( raised tank 5000+ 15,000 liter)	5000+ 15,000 liter	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2018/1865 dated 14/08/18, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval .

Signature of the Inspecting Officer

Signature of the Inspecting Officer

*[Signature]* 17/1/22

*[Signature]* 17/1/22

Name :- Rajinder Atwal  
Designation :- DO (CD)

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Signature]* 1. Pl. speak 2. Put up F.A.

*[Signature]* 18/1/22

*[Signature]* 1. spoken on 19/1/22.  
2. put up F.T. please

Asst (C)

*[Signature]* 19/1/22

As approved by *[Signature]* for kind renewal and *[Signature]* please.

*[Signature]* *[Signature]* 20/1/22

*[Signature]* 29/1/22

with attached MHA and fire control

