

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 65

Dated: 24 / 1 / 2022

FIRE SAFETY CERTIFICATE

Certified that **Milli Model School**, located at D-309, Dawat Nagar Abdul Fazal Enclave-I, Jamia Nagar, New Delhi 110025 comprised of One Block, Ground plus one upper floor & Second Block, Ground floor only owned/ occupied by Isha'at e Islam Trust (Regd.) was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/School/2018/SZ/2422 Dated 26-10-2018. The said premise was re-inspected by officer concerned of this department on 12/01/2022 in presence of Mr. Naeem (In charge) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 24 / 1 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 24 / 1 / 2022 at New Delhi by

**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Principal, Milli Model School, D-309, Dawat Nagar Abdul Fazal Enclave-I, Jamia Nagar, New Delhi 110025.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

n/4

INSPECTION REPORT

1	Name & Address of the Building	Milli Model School, D-309, Dawat Nagar Abdul Fazal Enclave-I, Jamia Nagar, New Delhi 110025.		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	1 st Block, Ground + one upper floor & 2 nd Block, Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2018/SZ/2422 Dated 26-10-2018		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	12/01/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Naeem (In charge)		
10	Year of construction	2000		
11	Applicant letter No.	Gmail dated 05/01/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required 06 m	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 m /0.75 m	1.50 m & 0.77 m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 No.	MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	Required	15 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7.	Automatic fire detection & alarming system.			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	-NA-	NA
12.	Yard Hydrants.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-

<ul style="list-style-type: none"> Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.		-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2018/SZ/2422 Dated 26-10-2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh
21/1/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

RMP
13/01

F. T.

DeFO (S2)



ADO BCP

As approved, F.T. letter is put up for your signature pl.

Sh
21/1/2022

DeFO (S2)



M S Ull