

C-26

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F,6/DFS/MS/School/2022/SZ/ 60

Dated: 21/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that the S.D.M.C. Primary Co-Ed School located at South Moti Bagh, New Delhi-110021. (ID-1959045) comprised of Ground & One Upper Floor owned / occupied by S.D.M.C. Primary School has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/SZ/2705 dated 14/12/2018. The premises was re-inspected by the officer concerned of this department on 05/01/2022 in the presence of Chowkidar and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 21/01/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 21/01/2022 at New Delhi by



(SUNIL CHAUDHARY)

o/c  
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. The Principal, S.D.M.C. Primary Co-Ed School, South Moti Bagh, New Delhi-110021.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

Ap/11  
**INSPECTION REPORT**

1. Name & address of the building: S.D.M.C. Primary Co-Ed School, South Moti Bagh, New Delhi-110021. (ID-1959045).
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus one upper floor.
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2018/SZ/2705 dated 14/12/2018
6. Fire Safety directives Letter No. : DOE Cir. Dated 01/03/2011
7. Date of inspection : 05/01/2022
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer from the building side : Chowkidar
10. Year of Construction : 2010
11. Applicant's letter received through email [Id-prismotibagh@gmail.com](mailto:Id-prismotibagh@gmail.com) dated 09/12/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	4m	4m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m / 0.75m	1.60 m each	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	Provided	MR
	c. Width Of Corridor	1.5m	Provided	MR
	d. Door Size	1.00m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	8	9	MR
	• Types	ABC /Co <sub>2</sub>	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

AKJ

2/22

First – Aid Hose Reels

• Total numbers on each floor	NA	NA	NA
• Length of hose reel hose	NA	NA	NA
• Nozzle diameter	NA	NA	NA

7. Automatic fire detection and alarming system

• Type of detector	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA

8. MOEFA

NA	NA	NA
----	----	----

9. Public Address System

NA	NA	NA
----	----	----

10. Automatic Sprinkler System

• Basements	NA	NA	NA
• Upper Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA

11. Internal Hydrants

• Size of riser/down-comer	NA	NA	NA
• Number of hydrants per floor	NA	NA	NA
• Hose Box	NA	NA	NA

12. Yard Hydrants

• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA

13. Pumping Arrangements

• Ground Level			
• Discharge of main pump	NA	NA	NA
➤ Head of main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Staring/Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace level			
➤ Discharge of pump	NA	NA	NA
➤ Head of the pump	NA	NA	NA
➤ Power supply	NA	NA	NA
➤ Auto starting of pump	NA	NA	NA

14. Captive water Storage for fire fighting

• Under ground tank capacity	NA	NA	NA
➤ Draw of connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA

*Handwritten signature*

M-13


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

General requirements for schools as per DOE Cir. Dated 01/03/2011.

1. Escape route .....:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring .....:- Conduit Wiring MCB and ELCB.....  
Electric circuit .....:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set ..... :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/SZ/2705 dated 14/12/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : D.O.

DO (SD)

DO (SD)

DO (SD)

DO (SD)

DO (ACT)

DO (SD)

DO (SD)

F.T. letter is attached please.

12/01/2022

M.S. all