

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/ /SZ/2022/ 27

Dated: 19/01/2022

FIRE SAFETY CERTIFICATE

Certified that the Building Centre for Cultural Resources and Training (**Except Auditorium**) Located at Plot 15/A, Sector – 7, Dwarka, New Delhi – 110075, comprised of small basement, Ground + 2 Upper Floor was issued FSC vide Letter No. F6/DFS/MS /2018/SZ/2214 Dated 01/01/2018. The premises was re inspected by the officers concerned of this department on 30/12/2021 in the presence of Sh. Suresh Karunik and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B “Educational” (**Except Auditorium**) with effect from 19/01/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/01/2022 at New Delhi by.


(Sunil Chaudhary)
Dy.Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Sh. Suresh Karunik, Centre for Cultural Resources and Training Located at Plot 15/A, Sector – 7, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

- 1 **The Auditorium shall not be occupied/ used for any purpose without getting FSC from this department.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/19
INSPECTION REPORT

1. Name & address of the building: Centre for Cultural Resources and Training
Located at Plot 15/A, Sector – 7, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Small Basement + Ground+ 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS /2018/SZ/2214 Dated 01/01/2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/96/487 Dated-10/04/1996
6. Date of inspection : 30/12/2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Suresh Karunik
9. Year of Construction : 2003
10. Applicant's letter No. Email Dated 09/12/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/16	Provided at site	Remarks
1.	Access of building			MR/NMR
	• Road width	06 mtr	Provided	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	4 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 m	4 Nos Provided Old Case	MR (old case)
	• Basements	1.5 m	2 Nos Provided Old Case	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	03 Nos.	03 Nos	MR
	e. Width Of Corridor	230 cm	1.70 mtr	MR Old Case
	f. Door Size	01mtr	01 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	26 nos.	Provided	MR
	• Types	ABC & CO ₂	CO ₂ , ABC, DCP	MR
	• IS marking	ISI marked	ISI marked	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	03 Nos. each floor	Provided	MR
		30 m	30 m	MR
	• Length of hose reel hose	05 mm	05 mm	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor near staircase	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Battery Backup	Provided	MR
	• Hooters' Location	Corridor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	03 Nos. each floor	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	02	02	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	➤ Head of main pump	56 mtr	56 mtr	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey pump out put	180 lpm	180 lpm	MR
	➤ Jockey pump head	56 mtr	56 mtr	MR
	➤ Standby Pump out put	1620 lpm	1620 lpm	MR
	➤ Standby Pump Head	56 mtr	56 mtr	MR
	➤ Auto starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the pump	40 mtr	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	10,000 ltr	50,000 ltr	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5000 ltrs each block	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

17	Standby power supply	Required	DG Set	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS /2018/SZ/2214 Dated 01/01/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Auditorium block is found under maintenance. If agreed the FSC may be issued to rest of the CCRT building except Auditorium block.

~~Signature of the Inspecting Officer~~
 Name Udai Vir Singh
 Designation ADO/DWK

~~Dot/SW~~

~~Kumar~~
 05/01/2022

F.A.

~~Dy CEO (S2)~~

~~A DO DWK~~

Sin AP letter is put up for sign

Plz

~~JW~~
 11/12/21

~~Dy CEO S2~~

~~[Signature]~~

M.S. CM