

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

No.F6/DFS/MS/2022/ 39

Dated : 27/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **C- Block Delhi High Court** located at **Shershah Suri Marg, New Delhi** comprised of **2B + Ground + 04 Upper floors** was earlier granted FSC/NOC by this department vide letter no. F6/DFS/MS/NDZ/2017/1393 dated 21/09/2017. Now, the premises was re-inspected by the officers concerned of this department on **17/01/22** in the presence of Sh. D.C.Gupta AE ( E) & Sh A.K.Jha JE ( E) and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **E- Business Occupancy (Office Building)** with effect from ~~27/01/2022~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 27/01/2022 at New Delhi by.

(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Executive Engineer (E), M-451 PWD, DHC& ND/Central, New Delhi.
2. The Assistant Engineer (E)-4511, PWD, DHC& ND/Central, New Delhi.
3. The Chief Architect, Department of Architecture & Environs, New Delhi.  
Municipal Council, Palika Kendra, New Delhi.
4. The Chairman,  
BMCC, Delhi High Court, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The basement shall be used as per building bye law concerned.

NIT  
INSPECTION REPORT

1. Name & address of the building C- Block, Delhi High Court, Shershah Suri Marg, New Delhi.
2. Type of occupancy:- Business Building  
2B + Gr. + 04 Upper floors
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/NDZ/2017/1393 dated 21/09/17
5. Fire safety directives No.- F6/DFS/MS/BP/2013/70 dated 03/05/13
6. Date of inspection:- 17/01/22
7. Name of the inspecting officer:- Sh.Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Sh. DC Gupta AE (E) & Sh. A.K.Jha JE (E)
9. Year of construction:- 2014-15
10. Applicant's letter No:- 23(68)/AE (E) /PWD/DHC & ND/Central/M-4511/2021-22/348 dated 20.12.21

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC-IV	Provided at site	Remarks MR/NMR
<b>1</b>	<b>Access to Building</b>			
	1) Road width	06 mtr.	12 mtr.	MR
	2) Gate width	05 mtr.	05 mtr.	MR
	3) Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	04 Nos.	04 Nos.	MR
	2. Basements	03 Nos.	03 Nos. & 2 ramps	MR
	B. Width of staircase			
	1. Upper floors	1.8 & 1.5 mtr.	02 nos. 1.8 mtr. & 02 Nos. 1.5 mtr.	MR
	2. Basements	1.8 & 1.5 mtr.	01 nos. 1.8 mtr. & 02 nos. 1.5 mtr. & 2 ramps	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1200 mm	1200 mm	MR
<b>3</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12ACPH	Provided	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	50	52	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each	03	03	MR

M/16

	floor			
	2) Length of hose reel hose	30 mm	30 mm	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	03	03	MR
	3) Hose box	03	03	MR
<b>12</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	04	04	MR
	2) Hose box	04	04	MR
<b>13</b>	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	220 LPM	220 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	70mtr.	70mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20000 ltr.	20000 ltr.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR

4/18

16	<b>Provision of Lifts</b>			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20	<b>Special Fire Protection System for Protection of special Risk, if any: Local Co2 flooding is panels.</b>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of DFS Rules 2010, the FSC/NOC issued vide letter no. F6/DFS/MS/NDZ/2017/1393 dated 21/09/17, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

*[Signature]* 19/1/22

Name :- Sh. Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

*[Signature]* 19/1/22

Name :- Sh. Ravinder Singh  
Designation : ADO (CC)



*[Signature]*  
Dy CFSO (CD)

*[Signature]*  
20/1/22

*[Signature]*  
Dy CFSO (CC)

*[Signature]*  
21/1

*[Signature]*  
21/1/2022

*[Signature]*  
ADDO

F.T. please.

*[Signature]*  
22/1/22

As approved, file put up for record and

Signature Please

Director  
21/1/22

*[Signature]*  
21/1/22

21/1/22  
23/6