

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/WZ/2022/ 37

Dated: 24/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **G3S Cinema, Plot No.6, Garg Trade Centre, Sector 11 Rohini, Delhi 110085**, running at 1st & 2nd floor of building comprised of **Basement Ground two upper floor plus projection room** was granted NOC by this department vide letter no. **F6.DFS/MS/Mall/2017/WZ/976 dated 07.07.2017**. The premises was re-inspected by the officers concerned of Fire Service on **04.01.2022** in the presence of **Sh. Satish Garg** and found that the said building have complied with fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the premise is fit for occupancy Group **"Assembly"(Cinema Audi 1 to 3)** with effective from **24/11/22** for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions as mentioned below.

Issued on **24/11/22** at New Delhi by


(Atul Garg)

DIRECTOR

Ph; 011-23414000

Copy to :-

1. Sh. Satish Garg, Shwet Garg Nirman Pvt. Ltd G3S Plot No.6, Garg Trade Centre, Sector 11 Rohini, Delhi 110085.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director on Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/ occupier shall apply for FSC on from 'I' for addition / alternation area of multiplex separately.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

- 1.Name & address of the building : G3S Cinema, Plot No.6, Garg Trade Centre, Community Centre, Sector 11 Rohini, Delhi 110085.
- 2.Type of Occupancy : Assembly
- 3.Type of Case : Renewal(03 Cinema halls at 1st & 2nd floor + projection room)
- 4.Details of Previous NOC : F6/DFS/MS/Mall/2017/WZ/976 Dated: 07.07.2017
- 5.Fire Safety directives letter No : 1432 Dated: 02.06.2017
- 6.Date of inspection : 04.01.2022
- 7.Name of Inspecting Officer : A. K. Sharma, ADO (Rohini) & D.B Mukherjee, DO (NW)
- 8.Name and designation of officers
From the building side : Sh. Satish Garg
- 9.Year of Construction : 2018
- 10.Applicant's letter No. : Online e-mail dated 27.12.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 6.0 mtr 6.0 mtr	12.0 mtr Provided Provided	M/R M/R M/R
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03 03	03 03	M/R M/R
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.50 mtr & 1.25 mtr 1.50 mtr	1.50 mtr & 1.25 mtr 1.50 mtr	M/R M/R
	f. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required --	Provided --	M/R --
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	1.50 mtr	Provided	M/R
	f. Door Size	1.50 mtr	Provided	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required NA NA NA	Required Provided NA NA NA	Provided MR NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust Fan Natural ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 No's ABC/CO ₂ /W.CO ₂ ISI marked	25 Nos 25/-/No's Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided Provided Provided Provided	M/R M/R M/R M/R
8.	MOEFA	Required	Provided	M/R
			Provided	M/R

1/2

9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System	Required	Provided	M/R
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		Required	Provided	M/R
		NA	NA	NA
11.	Internal Hydrants	150mm	Provided	M/R
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	2nos.	Provided	M/R
		2nos.	Provided	M/R
12.	Yard Hydrants	5nos.	Provided	M/R
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	5nos.	Provided	M/R
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2850 LPM	Provided	M/R
		60 M	Provided	M/R
		2 electric 1 stand by 0 Jockey	Provided	M/R
		180 LPM	Provided	M/R
		60 M	Provided	M/R
		2850 LPM	Provided	M/R
		60 M	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,50,000ltr	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		30,000ltr	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	Required	Provided	M/R
		NA	NA	NA
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Co2 Fire Extinguishers provided	MR

