

C-33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2022/SZ/ 76

Dated: 28 / 1 / 2022

FIRE SAFETY CERTIFICATE

Certified that **Gem Public School**, located at **64/1A, Street No-10, Molarband Extn. Badarpur, New Delhi- 110057** comprised of Ground plus one upper floor was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/School/SZ/2016/1847 Dated 28-12-2016. The said premise was re-inspected by officer concerned of this department on 19/01/2022 in presence of Sh. Sanjeev Sharma (Chairman) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 17/01/2005 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 28 / 1 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 28 / 1 / 2022 at New Delhi by



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

OK

Copy to: -

1. The Principal, Gem Public School, at 64/1A, Street No-10, Molarband Extn. Badarpur, New Delhi- 110057
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

2/10

INSPECTION REPORT

1	Name & Address of the Building	Gem Public School, 64/1A, Street No-10, Molarband Extn. Badarpur, New Delhi- 110057		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + one upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/SZ/2016/1847 Dated 28-12-2016		
6	Fire Safety Directives Letter No	DOE Circular 07/01/2005		
7	Date of Inspection	19/01/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Sanjeev Sharma (Chairman)		
10	Year of construction	2002		
11	Applicant letter No.	Outdoor diary no 5782 dated 12/01/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	4.5 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	Required	1.10 m & 0.76 m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 No	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	Open corridor	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	04 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-

N/A

<ul style="list-style-type: none"> Flow switch panel PA system panel Battery backup Building floor plan 	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.		

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6 MS/DFS/School/SZ/2016/1847 Dated 28-12-2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

Sh. Rajesh Kumar
25/1/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO(SD)~~

Sh. Rajesh Kumar
20/01/22

~~DeFO(SZ)~~

F.T.

Sh. Rajesh Kumar

~~ADO(BCP)~~

As approved, F.T. letter is put up for your signature pl

Sh. Rajesh Kumar
25/1/2022

~~Dufo/SZ~~

Sh. Rajesh Kumar

M.S. *Sh. Rajesh Kumar*