

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/Instt./2022/SZ/ 43

Dated: 28/01/2022

FIRE SAFETY CERTIFICATE

Certified that **Institute of Sanskrit & Vedic Studies** located at **Plot No 3, Phase- II, Institutional Area, Vasant Kunj, New Delhi - 110070** comprised of **Institute Block** for Education purpose (Basement, ground plus three upper floors) and **Health & Hostel Block** (Basement, ground plus two upper floors) owned/occupied by **Sri Ram Vittala Shikshana Seva Samiti** was issued FSC by this department vide letter No. F6/DFS/MS/Instt/2017/SZ/1029 Dated 13/07/2017. The premises was re-inspected by officers concerned of this department on 18/01/2022 in the presence of Mr. Madhwan and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Class "**Educational Building (Institute)**" as above with effect from 28/01/2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 28/01/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Authorized signatory, Institute of Sanskrit & Vedic Studies located at Plot No 3, Phase- II, Institutional Area, Vasant Kunj, New Delhi - 110070.
2. The joint Director, (L&I) DDA, Building Section, Vikas Sadan, INA, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

1/22

INSPECTION REPORT

1	Name & Address of the Building	Institute of Sanskrit & Vedic Studies at Plot No 3, Phase- II, Institutional Area, Vasant Kunj, New Delhi - 110070
2	Type of Occupancy	Educational Building (Institute)
3	Building Comprised of	Institutional Block No 1, Basement, Ground plus Three Upper floors and Health & Hostel Block No 2, Basement, Ground plus Two upper floors
4	Type of Case	Renewal
5	Details of Previous NOC	F6/DFS/MS/Instt/2017/SZ/1029 Dated 13/07/2017
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2002/2496 Dated 26/12/2002
7	Date of Inspection	18/01/2022
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)
9	Name & Designation of Officers from the building side	Mr. Madhwan
10	Year of construction	2014
11	Applicant letter No.	Gmail Dated 22/11/2021

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC /NNL Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	9 mtr	MR
	• Gate width	5 mtr	6 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	g) Number of Staircase			
	➤ Upper floors.	Block 1- 1 no's Block 2 - 2 no's	Block 1- 2 no's Block 2 - 2 no's	M/R
	➤ Basement floor.	Block 1- 3 + 1 ramp Block 2 - 2 no's	Block 1- 3 + 1 ramp Block 2 - 2 no's	M/R
	h) Width of Staircase			
	➤ Upper floors	Block 1- 1.50 mtr Block 2 - 1.50 m each	Block 1- 1.50 & 1.35 mtr Block 2 - 1.50 mtr each	M/R
	➤ Basement floor	1.50 mtr each	Block 1- 1.50 m each + 4.07 mtr ramp Block 2 - 1.50 mtr each	M/R
	i) Protection of exits			
	➤ Fire check door	Required	Provided & functional	M/R
	➤ Pressurization	-NA-	-NA-	-NA-
	j) No. of continuous staircase to terrace	One in each block	Two in each block	MR
	k) Width of corridor	-NA-	-NA-	-NA-
	l) Door size	01 m	01 m	M/R
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	Required	Provided & functional	M/R
	• Upper floors	NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI mark	22 Nos-	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	02 at each block	Provided	M/R
	• Length of hose-reel hose.	30 m	Provided	M/R

	<ul style="list-style-type: none"> Nozzle Diameter 	5 mm	Provided	M/R
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided & functional	M/R
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	1000 mm each block	Provided	MR
		01 no's	Provided	MR
		01 no's	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	03 no's	Provided	MR
		03 no's	Provided	MR
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	2850 LPM	Provided	MR
		75 m	Provided	MR
		One	Provided	MR
		180 LPM	Provided	MR
		75	Provided	MR
		2850 LPM	Provided	MR
		75 m	Provided	MR
		Required	Provided	MR
		900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

2/24

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 922 dated 23/04/2021.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Instt/2017/SZ/1029 Dated 13/07/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please

Handwritten signature
25/11/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

Handwritten signatures and initials
DFA (S2)
F-7

Handwritten signature
ADO (BCP)

As approved, F-7 letter is put up for your signature P1

Handwritten signature
25/11/2022

Handwritten signatures and initials
M.S. U

Handwritten signature
M.S. U