



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F.6/DFS/MS/Business/2022/SZ/ 40

Dated: 27/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Internet Data Centre, VSNL, Complex, Greater Kailash-I, New Delhi 110048 comprised Ground Plus Five Upper Floors owned/occupied by TATA Communications Limited was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Business/SZ/2019/130 dated 18/01/2019. The premise was re-inspected by the officers concerned of this department on 12/01/2022 in the presence of Mr. Sunil Kumar Jha and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Business Group-E**" with effect from 27/01/2022 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 27/01/2022 at New Delhi by

  
(ATUL GARG)  
DIRECTOR / DFS  
9/11

Copy to: -

1. Internet Data Centre, (Nextgen Tower) VSNL, Complex, Greater Kailash-I, New Delhi- 48.
2. The Executive Engineer (Bldg) SDMC, Jal Vihar, Lajpat Nagar, New Delhi 110024.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
2. The Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry." The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name& address of the building	: Internet Data Centre, VSNL Complex, Greater Kailash-I, New Delhi-48
2. Type of Occupancy	: Class-E "Business"
3. Type of Case	: Renewal
4. Comprised of	: Ground plus five upper floors
5. Details of Previous NOC	: F6/DFS/MS/Business/SZ/2019/130 dated 18/01/2019
6. Fire Safety directives letter No	: F6/DFS/MS/BP/2007/2181 dated 10/08/2007
7. Date of inspection	: 12/01/2022
8. Name of Inspecting Officer	: Sh. Rajesh Kumar ADO (BCP)
9. Name and designation of officers From the building side	: Mr. Sunil Kumar Jha
10. Year of Construction	: 2014
11. Applicant's letter No.	: Gmail dated 08/12/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>6m 5m 6m</p>	<p>Provided Provided Provided</p>	<p>MR MR MR</p>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>4 Nos -NA-</p>	<p>Provided -NA-</p>	<p>MR -NA-</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>1.5m -NA-</p>	<p>1.92,1.87,1.85 &amp; 1.9m -NA-</p>	<p>MR -NA-</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<p>Required Required (in two staircases)</p>	<p>Provided Provided</p>	<p>MR MR</p>
	d. No. of continuous staircases to terrace	4 Nos	Provided ✓	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1m (final exit)	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>Required Required Required -NA- Required</p>	<p>Provided Provided Provided -NA- Provided</p>	<p>MR MR MR -NA- MR</p>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour 12 a/c per hour</p>	<p>-NA- M. V. Provided</p>	<p>-NA- MR</p>
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<p>71 Nos ABC/W.CO<sub>2</sub>/CO<sub>2</sub> ISI</p>	<p>71 No's ✓ 18/18/35 No's Yes</p>	<p>MR MR MR</p>
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	<p>Four 36m 5mm</p>	<p>Provided Provided Provided</p>	<p>MR MR MR</p>
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	<p>Smoke &amp; Heat Required -NA- Required Required</p>	<p>Provided Ground Floor -NA- Provided Provided</p>	<p>MR MR -NA- MR MR</p>

1127

8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Above Floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm	150mm	MR
		4 No's	Provided	MR
		4 No's	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	6 No's	Provided	MR
		6 No's	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> </ul> </li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul>	2850LPM	Provided	MR
		60m	80m	MR
		Two	Provided	MR
		180 LPM	Provided	MR
		60m	80m	MR
		2850LPM	Provided	MR
		60m	80m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	2,00,000 Lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Lts.	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Battery backup</li> <li>Building Floor Plans</li> </ul>	-NA-	Provided	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	CO <sub>2</sub> Manual Flooding in LT & HT Panels	Provided	MR

N/28

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Business/SZ/2019/130 dated 18/01/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*RK*  
17/1/2022

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD)

*RK*  
17/01/22

*Defto (S2)*  
\_\_\_\_\_

*[Signature]*  
18/1/1

*CFO - (n. off)*

*Director*  
\_\_\_\_\_

*Any bld*

As approved, F.T. letter is put up  
for your signature pl

*Director*  
\_\_\_\_\_

*RK*  
21/1/2022

*m*