

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Petrol/2022/SZ/ 35

Dated: 24/01/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Ram Service Station (Dealer: Bharat Petroleum Corporation Ltd)** located at **opp. NSCI Mathura Road, New Delhi** comprised of Single Story Building owned/occupied by **M/s Ram Service Station** was issued FSC by this department vide letter No. F6/DFS/MS/NDZ/2018/SZ/2279 Dated 09/10/2018. The premise was re-inspected by the officer concerned of this department on 10/01/2022 in the presence of Sh. Sh. Ram Chand (Partner) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous Building (Group-J) 80 K.L Class "A" & 60 K.L Class "B"** with effect from 24/01/2022 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 24/01/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Administrative Officer, South Zone, South MCD, Green Park, New Delhi-110016.
2. M/s Ram Service Station (Dealer: Bharat Petroleum Corporation Ltd) at opp. NSCI Mathura Road, New Delhi

Conditions for the validity of Fire Safety Certificate: -

1. No Smoking and not to use Mobile phone sign board should be displayed in such a manner as to be easily readable by the persons.
2. No trade susceptible to cause Ignition petroleum vapors by generating heat, mechanical/electric spark should be allowed with in premises and its vicinity.
3. 04 nos of co2 gas type ISI capacity of 4.5 KG 02 nos of ABC stored pressure power type ISI capacity 05 kg and 01 number of AFFF type ISI capacity 20 ltrs provided should be maintained in proper working order all the time.
4. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguisher be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

1/19

INSPECTION REPORT

| | | | | |
|--------------|---|---|---------------------------------------|--------------------------------------|
| 1 | Name & Address of the Building | M/s Ram Service Station at opp. NSCI, Mathura Road, New Delhi | | |
| 2 | Type of Occupancy | Hazardous (Group-I) | | |
| 3 | Building Comprised of | Single Story Building | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/NDZ/2018/SZ/2279 Dated 09/10/2018 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 10-01-2022 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Sh. Ram Chand (Partner) | | |
| 10 | Year of construction | Nil | | |
| 11 | Applicant letter No. | Through Gmail Dated 21-12-2021 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 06 mtr Accessible -NA- | 15 mtr Accessible directly -NA- | MR MR -NA- |
| 2 | Number, width, type and arrangements of exits. | | | |
| | a. Number of Staircase | | | |
| | <ul style="list-style-type: none"> Upper floors Basement floor | -NA- -NA- | -NA- -NA- | -NA- -NA- |
| | b. Width of Staircase | | | |
| | <ul style="list-style-type: none"> Upper floors Basement floor | -NA- -NA- | -NA- -NA- | -NA- -NA- |
| | c. Protection of exits | | -NA- | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | -NA- -NA- | -NA- -NA- | -NA- -NA- |
| | d. No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e. Width of corridor | -NA- | -NA- | -NA- |
| | f. Door size | 1 mtr | 1 mtr | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- | -NA- -NA- -NA- -NA- -NA- |
| 4 | Smoke Management system. | | -NA- | |
| | <ul style="list-style-type: none"> Basement Upper floors | -NA- -NA- | -NA- -NA- | -NA- -NA- |
| 5 | Fire Extinguishers. | | | |
| | <ul style="list-style-type: none"> Total numbers Types ISI Marking | 13 Nos ABC/CO2/Mech. Foam trolley Required | Provided Provided Provided | MR MR MR |
| 6 | First Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter | -NA- -NA- -NA- | -NA- -NA- -NA- | -NA- -NA- -NA- |

| | | | | |
|-----|---|----------|----------------------------|------|
| 7 | Automatic Fire Detection and Alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 14. | Captive water storage for fire-fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 15. | No Smoking Signage (Hindi & English) | Required | Provided (Hindi & English) | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17 | Standby Power Supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

2/11

| | | | | |
|-----|---|------------------------|----------|------|
| 19. | Fire Control Room. | | | |
| | • Detector System Panel. | -NA- | -NA- | -NA- |
| | • Flow Switch Panel. | -NA- | -NA- | -NA- |
| | • PA system Panel. | -NA- | -NA- | -NA- |
| | • Battery backup | -NA- | -NA- | -NA- |
| | • Building floor plan | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | Fire buckers with send | Provided | MR |

The fire protection system such as fire extinguisher of different type and capacity, Fire buckets filled with loose dry sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign board were found displayed both Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/DFS/MS/NDZ/2018/SZ/2279 Dated 09/10/2018, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

AK
12/1/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO(BCP)

DO (SD)

AK
12/1/2022

Dy CPO (S) F.T.,
AK

ADO (B/C)

As approved, F.T. letter is put up for your signature.

Dy CPO (S) *AK*
MSD

AK
21/1/2022