

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/2022/SZ/ 42

Dated: 28/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that "SHAURYA" CRPF Officers Institute located at Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -110070 comprised of Basement, Ground plus One Upper Floor owned/occupied by Central Reserve Police Force, Govt. of India was issued FSC by this department vide letter No. F.6/DFS/MS/2019/SZ/37 dated 07-01-2019. The premises was re-inspected by officers concerned of this department on 18/01/2022 in the presence of Mr. Rajkumar (Inspector) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Class Assembly Building** as above with effect from 28/01/2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 28/01/2022 at New Delhi by

(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. Officer – in charge "SHAURYA" CRPF Officers Institute located at Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -110070.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

116

### INSPECTION REPORT

1	Name & Address of the Building	SHAURYA "CRPF Officers Institute at Plot No 8, Institutional Area, C-9, Vasant Kunj, New Delhi -70		
2	Type of Occupancy	Assembly Building		
3	Building Comprised of	Basement, Ground + 01 upper floor, Block 2 Not Constructed		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2019/SZ/37 dated 07-01-2019		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2003/1524 dated 09.07.2003		
7	Date of Inspection	18/01/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rajkumar (Inspector)		
10	Year of construction	1999		
11	Applicant letter No.	Outdoor diary no 5709 dated 06-01-2022		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	05 mtr	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	03 + 01 ramp	Provided	MR
	➤ Basement floor.	04 + 01 ramp	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50 m	1.50 m each & 1.2 m ramp	MR
	➤ Basement floor	1.50 m /1.25m	1.50m x 03 , 1.25 m & 5.9m ramp	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	01 No	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size (Exits in hall)</b>	1.5m	1.50 m (04no in auditorium)	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	34 Nos	MR
	• Types	ISI marked	Co2, ABC & DCP	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR

2/17

	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Required	Heat/Smoke/Beam	MR
		-NA-	Ground floor	-NA-
		Required	Fire control room	MR
		Required	Provided	MR
		-NA-	All Areas	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors.</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	150 mm	Provided	MR
		02 Nos	Provided	MR
		02 Nos	Provided	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	Required	Provided	MR
		Required	Provided	MR
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>			
		2850 LPM	Provided	MR
		70 M	Provided	MR
		01 No	Provided	MR
		180 LPM	Provided	MR
		70 M	Provided	MR
		2850 LPM	Provided	MR
		70 M	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	2,00,000 Ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltr	10,000 Ltr	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-



N18

	• Location			
19.	<b>Fire Control Room.</b>			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/2019/SZ/37 dated 07-01-2019, renewal under rule 35(6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD)

ADP  
26/01/22

DeFO (S2)

ADP

ADP/BI

As approved, f.t. letter is pending for your signature pl

ADP  
25/1/2022

Dy. C.S.O.

ADP

M.S. Cell