

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**


No F 6/DFS/MS/2022/School/WZ/ 88

Dated: 01/2/2022

FIRE SAFETY CERTIFICATE

Certified that the **Better Future Sachdeva Junior School, Sector 15, Rohini, Delhi-110089**, comprised of **Ground + Two upper floors** owned/occupied by **Better Future Sachdeva Junior School** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/2016/WZ/1339 Dated 01/09/2016**. The premises was re-inspected by the officer concerned of this department on **18.01.2022** in the presence of **Sh. Daksh Khurana** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no 3298-3398 dated 01.03.2011** and the building/ premise is fit for occupancy **Group B Educational** with effect from **01/2/22**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **01/2/22**..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Better Future Sachdeva Junior School, Sector 15, Rohini, Delhi-110089.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

INSPECTION REPORT

1. Name & address of the building : Better Future Sachdeva Junior School, Sector 15, Rohini, Delhi-110089.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 02 upper floors**)
4. Details of previous NOC : F.6/DFS/MS/School/2016/WZ/1339 Dated 01/09/2016
5. Fire Safety directives letter No : Direction of Education dated 01/03/2011
6. Date of inspection : 18.01.2022
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers from the building side : Sh. Daksh (Present)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : Online e-mail Dated 12.10.2021

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement dated 01/03/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	9meter	M/R
	• Gate width	Accessible	2.9	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.45 mtr& 0.80 mtr	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	01	M/R
	g. Width of Corridor	NA	NA	NA
	h. Door Size	Required	01 mtr with door Fitting	MR(Old Case)
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	07	07	M/R

M/R 1/17

	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltr	10000 ltr	M/R
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, and removal of shortcomings issued vide letter no. 7596 dated 19.12.2019 the FSC issued vide letter no. **F.6/DFS/MS/School/2016/WZ/1339 Dated 01/09/2016** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO (Rohini)**

Ajay
24/1/22

DO (NW)

Ajay
25/01/2022
DO (NW)

[Signature]
27/1/2022

Abol Rafiqi

FT letter is put up for kind perusal and signature please.

DO (NW)

[Signature]
31/1/2022

Ajay
28/1/22

use self