

C-22

FORM 'F': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/SZ/ 105

Dated: 02/02/2022

FIRE SAFETY CERTIFICATE

Certified that the C.M. Convent School located at KH.NO.11, Rao Mathura Prasad Road, Kapashera, New Delhi-110037 comprised of Ground & One Upper Floor owned / occupied by C.M. Convent School has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/SZ/2018/1038 dated 14/05/2018. The premises was re-inspected by the officer concerned of this department on 20/01/2022 in the presence of Smt. Sarita Yadav and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F6/Estate/CC/Fire/Safety/2011/ 3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 02/02/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010

Issued on 02/02/22 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. Smt. Sarita Yadav, C.M. Convent School, KH.NO.11, Rao Mathura Prasad Road, Kapashera, New Delhi-110037.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBI.-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBI.-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'F' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

N/11

1. Name & address of the building: C.M. Convent School, KH.NO.11, Rao Mathura Prasad Road, Kapashera, New Delhi-110037
2. Type of Occupancy : Educational, Group-B (School)
3. Building Comprised of : Ground plus one upper floor.
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/SZ/2018/1038 dated 14/05/2018
6. Fire Safety directives Letter No. : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01.03.11
7. Date of inspection : 20.01.2022
8. Name of the Inspecting Officer : A.K. JAISWAL (D.O.)
9. Name and designation of Officer
from the building side : Smt. Sarita Yadav
10. Year of Construction : 2009
11. Applicant's letter received through email ld-saurabh880029@gmail.com dated 19/01/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	6 mtr	MR
	• Gate width	Required	2 gate width 4mtr. & 4 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	Required	1.6 Mtr	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	Required	01 Nos	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	Required	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Open corridor	MR
5.	Fire Extinguishers			
	• Total numbers	Required	16 Nos	MR
	• Types	ABC /Co ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR



6. First - Aid Hose Reels

N/12

• Total numbers on each floor	NA	NA	NA
• Length of hose reel hose	NA	NA	NA
• Nozzle diameter	NA	NA	NA

7. Automatic fire detection and alarming system

• Type of detector	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA

8. MOEFA

NA	NA	NA
----	----	----

9. Public Address System

NA	NA	NA
----	----	----

10. Automatic Sprinkler System

• Basements	NA	NA	NA
• Upper Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA

11. Internal Hydrants

• Size of riser/down-comer	NA	NA	NA
• Number of hydrants per floor	NA	NA	NA
• Hose Box	NA	NA	NA

12. Yard Hydrants

• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA

13. Pumping Arrangements

• Ground Level			
• Discharge of main pump	NA	NA	NA
➤ Head of main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Staring/Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace level			
➤ Discharge of pump	NA	NA	NA
➤ Head of the pump	NA	NA	NA
➤ Power supply	NA	NA	NA
➤ Auto starting of pump	NA	NA	NA

14. Captive water Storage for fire fighting

• Under ground tank capacity	NA	NA	NA
➤ Draw of connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA

		N/13		
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/SZ/2018/1038 dated 14/05/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
24/01/2022

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (S.J.)

~~DO (SD)~~

King
27/01

~~DO (SD)~~

F. J.

~~DO (S.J.)~~

King
27/01

~~DO (S.J.)~~
By: CFO (SZ)

F.T. is added for sign. pl.

King

Ashok
01/02/2022

M.S. 04