

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 103

Dated: 02/02/2022

FIRE SAFETY CERTIFICATE

Certified that **Govt. Girls Senior Secondary School No-1, Sector-4, Dr. Ambedkar Nagar, New Delhi-110062 (School ID- 1923044)** comprised of 04 Building Blocks (A Block- Ground plus three upper floors, B- Block Ground plus one upper floor, C- Block Ground floor only & New Block, Ground plus three upper floors) owned/ occupied by Directorate of Education, Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2017/SZ/1351 Dated 08/09/2017. The said premises was re-inspected by officer concerned of this department on 28/01/2022 in presence of Mrs. Manju Gautam (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group – B with effect from 02/02/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 02/02/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Govt. Girls Senior Secondary School No 1, at Dr. Ambedkar Nagar Sector –IV, New Delhi 110062.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M/1/09

INSPECTION REPORT

1	Name & Address of the Building	Govt. Girls Senior Secondary School No-1, Sector-4, Dr. Ambedkar Nagar, New Delhi-110062, (School ID- 1923044)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Old Block-A -Ground + 03 upper floors Block-B - Ground + 01 upper floor Block-C- Ground floor only New Block - Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/1351 Dated 08/09/2017		
6	Fire Safety Directives Letter No	DOE dated 01/03/2011		
7	Date of Inspection	28/01/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Manju Gautam (Principal)		
10	Year of construction	1963 & 2016		
11	Applicant letter No.	E-mail dated 24/01/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	3.75 m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	Old block-A-1.45 & 1.50 m Old block-B - 2 m New block -1.80, 1.82 & 1.86 m	MR
	➤ Basement floor	-NA-	-NA-	NA
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	45 Nos	64 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			

2/19

INSPECTION REPORT

1	Name & Address of the Building	Govt. Girls Senior Secondary School No-1, Sector-4, Dr. Ambedkar Nagar, New Delhi-110062, (School ID- 1923044)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Old Block-A -Ground + 03 upper floors Block-B - Ground + 01 upper floor Block-C- Ground floor only New Block - Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/1351 Dated 08/09/2017		
6	Fire Safety Directives Letter No	DOE dated 01/03/2011		
7	Date of Inspection	28/01/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Manju Gautam (Principal)		
10	Year of construction	1963 & 2016		
11	Applicant letter No.	E-mail dated 24/01/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	3.75 m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	Old block-A-1.45 & 1.50 m Old block-B - 2 m New block - 1.80, 1.82 & 1.86 m	MR
	➤ Basement floor	-NA-	-NA-	NA
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Old block-A-02 nos. Old block-B-01 no. New block-03 nos.	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	45 Nos	64 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			

N/90

	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	2 + 3 Nos.	2 + 3 Nos. provided and functional	MR
		30 mtr	30 mtr	MR
		5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	100 mm	-NA-
		-NA-	Two	-NA-
		-NA-	Two	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Old block- 450 LPM New block- 450 LPM	Old block- 450 LPM X 2 (Provided and functional) New block- 450 LPM X 2	MR
		40 mtr	40mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18	Refuge Area			

1/9/


	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
19	Fire Control Room.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 661 dated 01/10/2020.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/School/2017/SZ/1351 Dated 08/09/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Designation : ADO (BCP)

~~DO (SD)~~

1/9/2022

DCFO/2

F.T.

ADO/B/P 

As approved, F.T. letter is put up for your signature pl

1/12/2022

DCFO/2



M.S. cell