

616

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**


No. F6/DFS/MS/School/WZ/2022/ 95

Dated: 01/2/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Kulachi Hansraj Model School**, Located at A-Block, Primary School, **Ashok Vihar, Phase-III, Delhi-110052**, comprised of **Ground + 02 Upper Floors** was issued FSC by this department Vide Letter No. F6/DFS/MS/School/2018/136 dated 23.01.2018. The said premises was re-inspected by the officer concerned of this department on 24.01.2022 in the presence of Sh. Rakesh Kumar (Maintenance Supervisor) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Circular no. 3298 to 3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 01/2/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on ..... at New Delhi by.

  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Kulachi Hansraj Model School, Located at, A-Block, Primary School, Ashok Vihar, Phase-III, Delhi-110052.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employces shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: **Kulachi Hansraj Model School**, Located at, **A-Block, Primary School, Ashok Vihar, Phase-III, Delhi -110052**
2. Type of Occupancy: Educational (**2-Block =Ground + 2 Upper Floor**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/136 dated 23.01.2018
5. Fire Safety directives Letter No. : DOE CR-/3298 to 3398 dated 01.03.2011
6. Date of inspection : 24.01.2022
7. Name of the Inspecting Officer : S.P. Bhardwaj, DO
8. Name and designation of Officer  
from the building side : Sh. Rakesh Kumar (Maintenance Supervisor)
9. Year of Construction :1975
10. Applicant's letter No. : email dated 17.01.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	CR-/3298 to 3398 dated 01.03.2011/letter dated 23.01.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	09 m	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 in each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5mtrs. Each	BL-1=1x121cm,1x127cm BL-2=1x154cm,1x120cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	215cm&243cm Provided	MR
	f. Door Size	1 mtr.	110 cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements Syst.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	19 nos.	38 Provided	NMR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2nos (Each Block)	02 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system	NA	NA	NA
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hyd/floor</li> <li>Hose Box</li> </ul>	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450lpm	Provided	MR
		40Mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10000Ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA

N/17

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/136 dated 23.01.2018 is recommended under rules 37 of the Delhi Fire Service Rules 2010 under the DFS Act 2007.

S.P. Bhardwaj  
Divisional Officer

*S.P. Bhardwaj*  
24/1/22

~~Do work / diff~~  
~~Defo / w2~~

*[Signature]*  
3/1/2022

~~Do work~~

FT is put up for signature plse

~~Defo / w2~~

*[Signature]*  
11/2/2022

*S.P. Bhardwaj*  
1/2/22

next call