

C-38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No. F6/DFS/MS/BNQT/WZ/2022/ 03

Dated: 18 / 01 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. **Mehak Banquet (A unit of Amour Banquets)** located at **Plot No. 43, Road No. 35, Main Rohtak Road, West Punjabi Bagh, New Delhi-110026.** is running at Upper Ground floor & First floor of a Building comprised of Basement + Stilt + Upper Ground + 03 Upper floors, Owned/Occupied by M/s. **Mehak Banquet** was issued FSC Vide letter No. F6/DFS/MS/WZ/2018/BNQT/2669 dated 10/12/2018 for (Upper Ground floor & First Floor only). The building/premises was re inspected by the officer concerned of this department on 07/01/2022 in the presence of Sh. Rohit Khochar (Owner) and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule 2010 and that the premises is fit for occupancy class "Assembly" Group D (**Upper Ground Floor & First Floor Only**) with effect from 18/01/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 conditions Printed Overleaf.

Issued on ... 18/01/2022 at New Delhi by.

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

13/01/2022

Copy to: -

1. The owner/ Occupier, M/s. Mehak Banquet (A unit of Amour Banquets) Plot No. 43, Road No. 35, Main Rohtak Road, West Punjabi Bagh, New Delhi-110026.  
**MHA Portal ID No. -2021091321261.**
2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi -110027.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. This NOC is valid for Upper Ground floor & First Floor only.

2/25  
**INSPECTION REPORT**

1. Name & address of the building : Mehak Banquet ( A unit of Amour Banquets)Plot No. 43,Road No. 35, Main Rohtak Road, West Punjabi Bagh, New Delhi-110026.
2. Type of Occupancy : Assembly(Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2018/BNQT/2669 dated10/12/2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 07/01/2022
7. Name of the Inspecting Officers :Sarabjeet SinghADO(MN)
8. Name and designation of officers from the building side : Sh. Rohit Khochar(Owner)
9. Year of Construction :2014 (As per prev. Insp. Rep. dtd.-04/12/2018)
10. Applicant's letter No. : Online Application ID No. 2021091321261 dated 08/11/2021

The said Banquet Hall is running at Upper Ground floor & 1<sup>st</sup> floor in a Building comprised of Basement, Stilt, Upper Ground + 03 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/ As per prev. Insp. Rep. dtd.-04/12/2018	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On main road	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	03 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1 X 2m,1X1.5m	1X 205 cm,1X1.5m1X1 m	MR
	• Basements	NA	150cms,156 cm,	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	01	02 Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2X 2m,	UGF(3exit)-205cm,200cm,168cm, FF-(2 exit)-200cm,200cm	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	NR	Provided	MR
	• Sprinkler above false ceiling	NR	Provided	MR
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NR	2280 lpm	NR
	➤ Head of Main pump	NR	70 m Provided	NR
	➤ Number of main pumps	NR	01 Provided	NR
	➤ Jockey Pump out put	NR	180 lpm Provided	NR
	➤ Jockey pump head	NR	70 m Provided	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NR	54,000 ltrs Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR



Provision of Lifts.				
76	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NR	NR	NR(as lift is terminating at stilt floor)
		NR	NR	NR
		Required	Provided	MR
		NR	Provided	NR
		NR	NR	NR
17	Standby power supply	Required	Provided	MR
18 Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19 Fire Control Room				
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2018/BNQT/2669 dated- 10/12/2018 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

350/ADO/MN  
11/01/2022  
Documst)  
on m/ Risk

*[Signature]*  
10/01/2022

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

*[Signature]*  
F.T.

ADO (MN)

Sir, F.T is put up for your personal & Signature please.

*[Signature]*  
M.S.

*[Signature]*

*[Signature]*  
13/01/2022  
ADO (MN)

M.S. *[Signature]*  
Uploaded *[Signature]*  
with/hon