

52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HQS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110001


No. F.6/DFS/MS/GH/2022/SZ/ 64

Dated: 01.12.2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Nattan Niwas Guest House** located at **Plot No 30, Jangpura Road, Bhogal New Delhi 110014** Comprised of Basement (other property) **Ground floor (Rec. + 04 G/Room) 1st to 2nd Floor (05 Guest room each) 3rd floor owner residence, 4th floor - 02 rooms** Sealed by (owner) Total 14 guest rooms was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/GH/SZ/2019/285 dated 04-02-2019. The premise was re-inspected by the officer concerned of this department on 25/01/2022 in the presence of Mr. Parmanand Saini (owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential, Group-A**" (**Guest House for ground plus two upper floor with 14 Guest room**) as above with effect from 01/12/2022 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/12/2022 at New Delhi by



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. M/s Nattan Niwas Guest House at Plot No 30, Jangpura Road, Bhogal New Delhi 110014
2. The Joint Commissioner of Police (Lic/Branch), 1st Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID 2022011300718 dated 13-01-2022)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The occupancy of 4th floor is not allowed as per the provision contained in clause 7.31 of UBBL-2016.

INSPECTION REPORT

1	Name & Address of the Building	M/s Nattan Niwas Guest House located at Plot No 30, Jangpura Road, Bhogal New Delhi 110014		
2	Type of Occupancy	Group- A "Residential & Lodging"		
3	Building Comprised of	Basement (other property) Ground plus two Upper Floors , 3 rd floor owner residence, & 4 th floor- 02 rooms sealed.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/GH/SZ/2019/285 dated 04-02-2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25/01/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Parmanand Saini (owner)		
10	Year of construction	1970	Ground floor 4 G/Room, 1 st & 2 nd floor (5 G/Room each, Total 14 Guest rooms	
11	Applicant letter No.	MHA Portal ID 2022011300718 dated 13-01-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL /NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	Provided	MR
	• Gate width	N/A	Directly accessible	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01	01	MR
	➤ Basement floor.	01	01	MR
	b) Width of Staircase			
	➤ Upper floors	1.0 mtr	1.04 mtr	MR
	➤ Basement floor	1.0 mtr	1.04 mtr	MR
	c) Protection of exits	The occupancy per person at per floor is less than of 10 person hence the requirements under clause 7.31 of UBBL is not applicable		
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required 01	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1m	1m (final exit)	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	The occupancy per person at per floor is less than of 10 person hence the requirements under clause 7.31 of UBBL is not applicable		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	08 Nos	08 Nos	MR
	• Types		ABC, W.CO ₂ & CO ₂	MR
	• ISI Marking	ISI marked	Yes	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 no at each floor	Provided	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter	Hose Reels	5mm	MR
7	Automatic fire detection & alarming system.	The occupancy per person at per floor is less than of 10 person hence the requirements under clause 7.31 of UBBL is not applicable		
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A

8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	Area 77.75 m ²	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40 m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

