

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/School/NDZ/2022/ 100

Dated: 01/2/22

FIRE SAFETY CERTIFICATE

Certified that the (1) Rukmani Devi Jaipuria Public School, (2) Seth Beni Pershad Jaipuria Prep. School located at 23-25, Rajpur Road, Delhi-52, comprises of Basement + Ground+ 03 upper floor was granted FSC by this department vide letter no.F6/DFS/MS/2019/School/123 dated 17.01.2019. The premises was re-inspected by Assistant Divisional Officer (SPM) from this department on 27.01.2022 in presence of Mr. S.K. Saxena, Principal & Mr. Rohit Chopra, Manager and found that the school building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of class **Group B 'Educational Building'** with effect from 01/2/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on... 01/2/22 ... at New Delhi by.


1/2/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

o/c Rb
31.01.22

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The principal(1) Rukmani Devi Jaipuria Public School, (2) Seth Beni Pershad Jaipuria Prep. School located at 23-25, Rajpur Road, Delhi - 52.

Conditions for the validity of Fire Safety Certificate: -

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	(1) Rukmani Devi Jaipuria Public School & (2) Seth Beni Pershad Jaipuria Prep. School located at 23-25, Rajpur Road, Delhi -52		
2	Building is comprised of	Basement + Ground+ 03 upper floor		
3	Type of occupancy	Educational		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/2019/School/123 dated 17.01.2019		
6	Fire safety direction letter no.	NA		
7	Date of inspection	27.01.2022		
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (SPM)		
9	Name of the designation of officer From the building side	Mr. S.K. Saxena, Principal & Mr. Rohit Chopra, Manager		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor diary no. 5785 dated 13.01.2022		
S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/Existing fire safety arrangement	Provided at site	Remarks MR/NM R
1	Access to Building:			
	Road width	6 mtrs.	24 mtrs.	MR
	Gate width	5 mtrs.	5 mtrs.	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	05 nos.	05 nos.	MR
	b Basement	05 nos.	05 nos.	MR
	B Width of staircases			
	a Upper floor	1.5 mtrs.	04 Nos. 1.70 mtrs. 01 Nos 1.10 mtrs (Iron)	MR
	b Basement	1.5 mtrs.	04 Nos. 1.70 mtrs. 01 Nos 1.10 mtrs (Iron)	MR
	C Protection of exits	NA	NA	NA
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	03 nos.	04 nos.	MR
	E Width of corridor	1.5 mtrs.	2.67 mtrs.	MR
	F Door size	1 mtrs.	1 mtrs.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basement	Natural/ Mechanical	Mechanical (Exhaust fans)	MR
	B Upper floor	Natural/ mechanical	Natural	MR

5. Fire Extinguisher:				
A	Total numbers	66 nos.	66 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	Required	Provided	MR
6 First-aid-Hose Reel:				
A	Total numbers of each floor	04 nos.	04 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	5 mm	5 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8 MOEFA:				
		NA	NA	NA
9 Public Address System:				
		Required	Provided	MR
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	04 nos.	04 nos.	MR
C	Hose box	04 nos.	04 nos.	MR
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
I	Pump house access	NA	NA	NA
2 Terrace Level				
A	Discharge of pump	900 & 450 LPM	2 x 900 LPM 2 x 450 LPM	MR
B	Head of the pump	30 mtrs.	30 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	20,000 ltrs.	20,000 ltrs.	MR	
B	Draw-off connection	Required	Provided	MR	
C	Fire service inlet	Required	Provided	MR	
D	Access to tank	Required	Provided	MR	
E	Overhead tank capacity	50,000Ltrs	50,000 Ltrs.	MR	
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
A	Pressurization of lift shaft	NA	NA	NA	
B	Pressurization of lift lobby	NA	NA	NA	
C	Communication in lift car	NA	NA	NA	
D	Firemen's grounding switch	NA	NA	NA	
E	Lift signage	NA	NA	NA	
17	Standby Power Supply:		Required	Provided	MR
18	Refuge Area:				
A	Total area	NA	NA	NA	
B	Location	NA	NA	NA	
19	Fire Control Room:				
A	Detector system panel	NA	NA	NA	
B	Flow switch panel	NA	NA	NA	
C	PA system panel	NA	NA	NA	
D	Battery backup	NA	NA	NA	
E	Building floor plans	NA	NA	NA	
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA	

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA) Provided but not functional (PNF)

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/2019/School/123 dated 17.01.2019 renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)

28/1/22

Dy. CEO (MS2)

(Signature) 31/1/22

ADO (SPM) FI is put up pls

Dy. CEO (MS2)

(Signature) 1/2/22

31-01-22

raj

