

C-28

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6 DFS/MS/School/2022/ 127

Dated: 8/02/2022

FIRE SAFETY CERTIFICATE

Certified that the Building N.K Bagrodia Global School, Located at, Sector – 17, Phase – II , Dwarka, New Delhi – 110078 comprised of Ground + 3 Upper Floor was issued FSC vide Letter No. F6 DFS/MS/School/2018/SZ/2321 Dated-15/10/2018. The premises was re inspected by the officer concerned of this department on 27-01-2022 in the presence of Mrs. Jaishree Nawani and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B “Educational” with effect from 08/02/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/02/22 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, N.K Bagrodia Global School, Sector – 17, Phase – II , Dwarka, New Delhi – 110078.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

14-17
INSPECTION REPORT

1. Name & address of the building: N.K Bagrodia Global School, Located at, Sector – 17, Phase – II , Dwarka, New Delhi – 110078.
2. Type of Occupancy : Educational (Ground+3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/2321 Dated- 15/10/2018
5. Fire Safety directives Letter No. DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 27-01-2022
7. Name of the Inspecting Officer : Udai vir Singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mrs. Jaishree Nawani
9. Year of Construction : Before 2011-2012
10. Applicant's letter No. : Email Dated 20/01/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided	MR
	• Width of internal road	NA	06 mtr	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	06 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	153cm,150cm,147cm,146cm,129 cm &128cm, Including Railing	MR old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	150 cm	Old Case	MR(Old case)
	f. Door Size	100cm	106 cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	30 ac charge	NA	NA
	• Upper floors	12 ac charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	8 nos. at each floor	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ABC & CO ₂ ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	DG set 125 KVA	NA
	• Hooters' Location	NA	In Staircase	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	04	NA
	• Hose Box	NA	04	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	30 Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

11-19

14.	Captive water Storage for fire fighting:		
	• Underground tank capacity	NA	NA
	➤ Draw off connection	NA	NA
	➤ Fire service inlet	NA	Provided
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10,000Ltr	20,000 ltr Provided
15	Exit Signage	Required	Provided
16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided
	➤ Lift Signage	Required	Provided
17.	Standby power supply	NA	DG Set 100 KVA
18.	Refuge Area		
	➤ Total area	NA	NA
	➤ Location	NA	NA
19.	Fire control room		
	➤ Detector system panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA System Panel	NA	NA
	➤ Battery backup	NA	NA
	➤ Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguishers for electric panels

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/2321 Dated-15/10/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Abhishek Singh*

Designation *ADO/DWTG*

[Signature]

[Signature]
01/10/2022

Dy cfo (S2)

[Signature]

ADO (DWTG)

F.T.

1/2