

E-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2022/NDZ/123

Dated: 07/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Alfalah Islamic School, located at Veer Abdul Hameed Raod, B-Block, North Ghonda, Delhi-110053, school is running on ground plus one upper floor of the building comprised of ground plus two upper floor owned/occupied by M/s Alfalah Islamic School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/2351 dated 17/10/18. The school building was re-inspected by the officer concerned of this department in presence of Mr. Shaquib Yasin, Manager of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that school building is fit for ground plus one upper floor occupancy class "B" 'Educational Building' with effect from 07/02/2022 for a period of **three** years, subject to conditions, printed Overleaf.

Issued on 07/02/2022 at New Delhi by


7/2/22

**(Dr S.K Tomar)
Dy. Chief Fire Officer**

To,

The Manager
Alfalah Islamic School,
Veer Abdul Hameed Raod, B-Block,
North Ghonda, Delhi-110095

Copy:-

The Joint Director of Education, (Land & Estate)
Directorate of Education, Lucknow Road,
Delhi-110054



o/c

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/12


1. Name & address of the building : Alfalah Islamic School, Veer Abdul Hameed Raod, B-block, North Ghonda, Delhi-110053.
2. Building is comprised of : Ground + 2 (Running on G+1 only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/2351 Dt- 17/10/18
6. Fire Safety direction letter No : Dir. of Edu. Circular Letter No.262-362 Dated-17/01/05
7. Date of Inspection : 01/02/2022
8. Name of the Inspecting officer : ADO Mehmood
9. Name and designation of officer from the building side : Mr. Shaquib Yasim(Manager)
10. Year of Construction : 1983
11. Applicant's letter No : Letter No.–Nil, Dated- 21/01/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	04 mtr.	MR/old case
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 Nos.	02 Nos.	MR
	• Basement	N/A	N/A.	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.1 m & 0.75 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 M	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular No. 262-362 dated 17/01/2005, it is recommended to renewal Fire Safety Certificate under rule 35 of Delhi Fire Service rule 2010.


 Signature of the Inspecting Officer
 Name - Mehmoed
 Designation - A.D.O(T.P)

Dy. CFO(NDZ)



 3/2/22


 871
 Date 3/2/22
 7/2/22
 ADO(T.P)

Sr. A.P.T. Delhi pur. v. for signature please

Dy. CFO (NDZ)


 7/2/22


 09/02/2022
 ADO(T.P)

MS