

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/WZ/2022/27

Dated: 03/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s **Mealodrama Modern Bistro (A unit of TR Sawhney Food & Beverages)** located at 1st Floor, A-6, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi of a Building comprised of Basement + stilt + Upper Ground + 03 Upper Floors, Owned/Occupied by M/s. Mealodrama Modern Bistro (A unit of TR Sawhney Food & Beverages), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 21/01/2022 in the presence of Sh. Gajender Singh Rawat and found that the said building is fit for occupancy class "Assembly" Group D (for first floor only) with effect from 03/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed Overleaf.

Issued on 03/02/2022 at New Delhi by.


(Ajay Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/occupier M/s Mealodrama Modern Bistro (A unit of TR Sawhney Food & Beverages) located at A-6, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi. **MHA Portal ID No. 2021121628718.**
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adclcp.lic-dl@nic.in).
3. The Dy. Commissioner, South DMC, West Zone, Shivaji Place, Tagore Garden Extn New Delhi.
4. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowestzone@gmail.com)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. This NOC is Valid for First floor only.
9. No Electric Gadgets shall be installed in the staircases.

21/15

INSPECTION REPORT

1. Name & address of the building : M/s Mealodram (A unit of TR Sawhney Food & Beverages)
A-6, Main Najafgarh Road, Vishal Enclave, New Delhi
2. Type of Occupancy : Assembly/ Restaurant (Eating House)
3. Type of Case : New (Basement, Stilt, Upper Ground Floor, 1st floor, 2nd floor & 3rd Floor) (Restaurant is opening at 1st Floor Only)
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : NBC (Part-IV)
6. Date of inspection : 21/01/2022
7. Name of the Inspecting Officers : D.O. (West) & ADO (MN)
8. Name and designation of officers from the building side : Mr. Gajinder Singh Rawat
9. Year of Construction : 2015 (As Per MHA Portal)
10. Applicant's letter No. : Online Application No. 2021121628718 dated 16/12/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mtr	On Main Road	MR
	• Gate width	On Main Road	On Main Road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 mtr x 2	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	Required	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.50 mtr x 2	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	02	04	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

84

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30mtr	30mtr	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	Provided	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	Provided	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	Provided	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	Provided	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	Provided	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NR	NR	NR
	<ul style="list-style-type: none"> Draw-off connection 	NR	NR	NR
	<ul style="list-style-type: none"> Fire service inlet 	NR	NR	NR
	<ul style="list-style-type: none"> Access to tank 	NR	NR	NR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued by this department vide Letter no. F6/DFS/MS/EH/2020/102 dated- 24/01/2020 & F6/DFS/MS/EH/WZ/2021/463 dated 18/10/2021 have been compiled.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
27/01/2022

Signature of the Inspecting Officer
Name: M.K.Chattopadhyay
Designation: DO (WZ)

[Signature]
27/01/22

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

376/ADO/MN
27/01/2022
D.O. (WEST)/345
DATED 27/1/2022

[Signature]
DO (WZ)

[Signature]
21/1/2022

[Signature]

[Signature]

[Signature]
1/2/2022

FI Pls

one copy

1/2/22
605

[Signature]

[Signature]
02/2/2022

ADO (MN)