

6-33

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2022/ 111

Dated: 03/2/2022

FIRE SAFETY CERTIFICATE

Certified that the Building Govt. Girl/ Boys Sr. Sec. School, Located at Bindapur (DDA Flats). New Delhi-110059, comprised of five blocks each block is having **Ground+ One Upper Floor** owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2018/SZ/692 Dated 13/04/18. The premises was re inspected by the officer concerned of this department on 19/01/2022 in the presence of Ms. Rajni Sharma (Vice Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the condition given below.

Issued on 03/2/22 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Girl/ Boys Sr. Sec. School, at Bindapur (DDA Flats). New Delhi-110059 (School ID-1618060)
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Govt. Girl/ Boys Sr. Sec. School, Located at Bindapur (DDA Flats). New Delhi-110059(School ID-1618060)
2. Type of Occupancy : Educational 05 blocks (Ground+ One Upper Floor) **03 blocks interconnected at each floor level**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/692 Dated 13/04/18
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 19-01-2022
7. Name of the Inspecting Officer: Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Rajni Sharma (Vice Principal)
9. Year of Construction : 1990 (Old block), 2007 (New block) & Block – 3,4&5 (2015-16)
10. Applicant's letter No. : Email dated 29/12/2021

No. of Students=2756
No. of class rooms=40
Plot area=10500 sqm ²
Covered area=5414 sqm ²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 no in OB & Blk -3 & 02 no in NB, 01 no in 4&5	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150 cm/additional staircase of 75 cm if less than 150 cms	2x190cm in NB, 150, 145 & 137 cms in OB & blk-3, 150cm in blk-4 & 150cm in blk-5	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	150 cm	155 cm in NB, 152 cm each in OB & blk 3, 170 cm in blk - 4 & 175 cm in blk 5	MR
	f. Door Size	100 cm	114 cm in NB, 98 cm in OB & 110 cm & 100 in blk 3, 110 cm in blk - 4 & 110 cm in blk 5 (double door in each block)	MR Old case

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	32 nos.	40 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> • Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

2/19

20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/692 Dated 13/04/18 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADDO/MS

1/10
29/1/22

ADDO/MS

ADDO/MS
25/01/2022

Dy cfo (S2)

F-7

ADDO/MS

Sir AT letter is put up for

sign ple.

1/10
11/2/22

Dy cfo/S2

ADDO/MS
2/2/2022

M.S. cell